


TAXIWAY TYPICAL SECTION "A-A" (NOT TO SCALE)

- ① 401-BITUMINOUS SURFACE COURSE (2" DEPTH)
- ② 603-TACK COAT (0.05 TO 0.15 GAL./S.Y.)
- ③ 201-BITUMINOUS BASE COURSE (2-3" LIFTS)
- ④ 602-PRIME COAT (0.35 GAL./S.Y.)
- ⑤ 209-CRUSHED AGGREGATE BASE COURSE (6" DEPTH)
- ⑥ 208-OVERSIZED AGGREGATE (8" DEPTH)
- ⑦ 156-SEPARATION FABRIC (IF REQUIRED)

LEGEND

	EXISTING PAVEMENT
	PROPOSED IMPROVEMENTS
	EXISTING PAVEMENT TO BE REMOVED



209-CRUSHED AGGREGATE BASE COURSE NOTES:

THE CRUSHED AGGREGATE BASE COURSE (209) SHALL BE PLACED IN ACCORDANCE WITH ITEM 209 "CRUSHED AGGREGATE BASE COURSE" AS STATED ON PAGE 45 OF THE SUPPLEMENTAL SPECIFICATIONS AND RECURRING SPECIAL PROVISIONS, ADOPTED JULY 1, 2004.

THE BASE COURSE MATERIAL (CA-6) WILL BE USED TO CONSTRUCT A BASE COURSE FOR THE PROPOSED TAXIWAY "A" AND "C" WIDENING, THE BASE COURSE WILL BE 6" IN DEPTH AND COMPACTED TO NOT LESS THAN 95 PERCENT DENSITY.

THE PROPOSED AGGREGATE FOR THE BASE COURSE MATERIAL SHALL MEET THE REQUIREMENTS OF GRADATION "B" IN TABLE 1 OF THE SUPPLEMENTAL SPECIFICATIONS.

209-3.2 EQUIPMENT ADD THE FOLLOWING PARAGRAPHS TO THIS SECTION:

"PROVISIONS SHALL BE MADE BY THE CONTRACTOR FOR FURNISHING WATER AT THE PLANT AND AT THE SITE OF THE WORK BY EQUIPMENT OF AMPLE CAPACITY AND OF SUCH DESIGN AS TO ASSURE UNIFORM MIXING AND APPLICATIONS."

THE CONTRACTOR WILL PROVIDE THE RESIDENT ENGINEER A PROCTOR CURVE SHOWING OPTIMUM DENSITY AND MOISTURE FOR THE SUPPLIED BASE COURSE MATERIAL.

THE COMPACTION CONTROL TEST TO BE USED SHALL BE FAA COMPACTION CONTROL TEST T-611 FOR AIRCRAFT WEIGHING MORE THAN 60,000 LBS.

209-4.1 DELETE THE FIFTH SENTENCE AND REPLACE IT WITH THE FOLLOWING:


"IF AT THE TIME THE AGGREGATES ARE WEIGHED THEY CONTAIN MORE THAN SIX (6) PERCENT OF ABSORBED AND FREE MOISTURE BY WEIGHT, A DEDUCTION FOR THE MOISTURE IN EXCESS OF THIS AMOUNT SHALL BE MADE IN DETERMINING THE PAY QUANTITY."

APR 10, 2006 10:17 AM BAK I:\AIRPORTS\DEKALB\803-051\XVA\AIRPORT\SHETS\TWY-C\A-R-121CON.DWG

REVISION	DATE	BY



JFS Project No.	80305XXVAD_0800
Filename	R-121CON.DWG
Scale	1" = 50'
Date	01/05/05
LAYOUT	JMB 01/05/05
DRAWN	JMB 01/05/05
REVIEWED	CAH 02/22/06



WIDEN TAXIWAYS A & C FROM 35' TO 50'
PROPOSED CONSTRUCTION PLAN
STA. 111+00 TO STA. 116+00