

HIGH MAST POLE AND LUMINAIRE SCHEDULE

| POLE | | | | | | LUMINAIRE | | | | | | | |
|---------------------|-----------------|-----------|------------|--------------|-----------|----------------|---------|--------|----------|-------------------|------------------|-------------|-----------|
| LOCATION | | TYPE | HEIGHT (M) | FOUNDATION * | | IDENTIFICATION | | | QUANTITY | DISTRIBUTION TYPE | SHIELD SIZE (MM) | | WATT/VOLT |
| STATION (BASE LINE) | OFFSET (FROM B) | | | TYPE | DEPTH (M) | CONTROLLER | CIRCUIT | NUMBER | | | HOUSE SIDE | STREET SIDE | |
| 152+877.3 (I-74 EB) | 28.0 L | HIGH MAST | 30 | 2 | * | J | AB | 2 | 6 | M-C-V | N.A. | N.A. | 400/240 |
| 152+990.0 (I-74 EB) | 38.4 L | HIGH MAST | 30 | 2 | * | J | AB | 1 | 6 | M-C-II | 200 | 200 | 400/240 |
| 153+148.7 (I-74 EB) | 26.6 L | HIGH MAST | 30 | 2 | * | J | CD | 1 | 8 | M-C-II | 200 | 200 | 400/240 |
| 153+303.0 (I-74 EB) | 46.0 L | HIGH MAST | 30 | 2 | * | J | EF | 1 | 5 | M-C-II | 200 | 200 | 400/240 |
| 153+494.5 (I-74 EB) | 27.4 L | HIGH MAST | 30 | 2 | * | J | EF | 2 | 4 | M-C-V | N.A. | N.A. | 400/240 |
| 153+600.0 (I-74 EB) | 23.0 L | HIGH MAST | 30 | 2 | * | J | EF | 3 | 4 | M-C-V | N.A. | N.A. | 400/240 |
| 153+965.0 (I-74 EB) | 102.7 L | HIGH MAST | 30 | 2 | * | W | AB | 3 | 5 | M-C-V | N.A. | N.A. | 400/240 |
| 154+060.0 (I-74 EB) | 108.0 L | HIGH MAST | 30 | 2 | * | W | AB | 4 | 6 | M-C-V | N.A. | N.A. | 400/240 |
| 154+153.0 (I-74 EB) | 86.5 L | HIGH MAST | 30 | 2 | * | W | AB | 5 | 5 | M-C-II | 400 | N.A. | 400/240 |

* FOR TYPE 2 FOUNDATION DETAILS AND DEPTHS SEE SHT. 35.

LIGHTING SHEET 5 OF 41

| REVISIONS | | ILLINOIS DEPARTMENT OF TRANSPORTATION |
|-----------|------|---------------------------------------|
| NAME | DATE | |
| | | POLE AND LUMINAIRE SCHEDULE |
| | | |
| | | |
| | | |
| | | |
| | | |


alfred benesch & company
 CONSULTING ENGINEERS
 205 NORTH MICHIGAN AVENUE, CHICAGO, ILLINOIS 60601

DRAWN BY DJK
 CHECKED BY MKR
 DATE: 12/20/04

m:\p01557-3\lighting\contract\111100-7a-luminaire-schedule.dgn

12/14/04 PM

12/20/2004