



NOTES - HORIZONTAL DIRECTIONAL DRILLING

1. DIRECTIONAL DRILLING SHALL NOT COMMENCE UNTIL THE SHEET PILING HAS BEEN INSTALLED.
2. CONDUITS SHALL BE A MINIMUM OF 6 FEET BELOW BOTTOM OF LOCK CHANNEL. SEE CROSS SECTIONS.
3. CONDUITS SHALL PASS UNDER THE SHEET PILING SECTION THAT IS DRIVEN SHALLOW TO CLEAR THE CONDUITS UNDER THE LOCK CHANNEL. COORDINATE EXACT LOCATION WITH THE SHEET PILING INSTALLER.
4. STOPPING OR DISTURBING BOAT TRAFFIC IN THE LOCK CHANNEL SHALL BE KEPT TO AN ABSOLUTE MINIMUM. BOATS SHALL NOT BE BLOCKED FOR MORE THAN 15 MINUTES WHILE PERFORMING DIRECTIONAL DRILLING.

SYMBOLS

- E- UNDERGROUND ELECTRIC DUCTBANK
- T- UNDERGROUND TELEPHONE DUCTBANK
- S- UNDERGROUND SPARE CONDUIT FOR FUTURE NATURAL GAS LINE
- HH2 HANDHOLE

ABBREVIATIONS

- C CONDUIT
- GRD GROUND
- HH HANDHOLE
- (E) EXISTING
- PHG PNEUMATIC HYDRO GATE
- RGS RIGID GALVANIZED STEEL
- HDPE HIGH DENSITY POLYETHYLENE
- 2PDT TWO POLE, DOUBLE THROW

SITE PLAN
SCALE: 1" = 30'



DESIGNED BY RS
 CHECKED BY RS
 DRAWN BY LT
 CHECKED BY RS

Cochran & Wilken, Inc.
Consulting Engineers & Scientists
5202 South Skelm Street Road, Springfield, IL 62703-5143
Ph. (217) 595-4300

