



# Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

May 26, 2011

SUBJECT: Various Routes  
Project CMM-9003(822)  
Section 10-00251-00-MS (Oak Park)  
Cook County  
Contract No. 63538  
Item 200  
June 17, 2011 Letting  
Addendum (A)

TO PROSPECTIVE BIDDERS:

Due to clarify information necessary to revise the following:

**Proposal – Revised Index of Special Provisions.**  
**Added pages 112, 113 and 114 to the Special Provisions.**

**Plans – Revised sheets 10, 11 & 12.**

Prime contractors must utilize the enclosed material when preparing their bid and must include any Schedule of Prices changes in their bidding proposal.

Bidders using computer-generated bids are cautioned to reflect any and all Schedule of Prices changes, if involved, into their computer programs.

Very truly yours,

Scott Stitt  
Acting Engineer of Design and Environment

A handwritten signature in black ink, appearing to read "Scott Stitt AE". The signature is fluid and cursive, with "AE" written in a smaller, more formal script at the end.

By: Ted B. Walscheger  
Engineer of Project Development  
and Implementation

Various Locations  
Cook County  
Village of Oak Park  
10-00251-00-MS

## SPECIAL PROVISIONS

### INDEX OF SHEETS

LOCATION OF PROJECT .....	1
DESCRIPTION OF PROJECT.....	1
MAINTENANCE OF ROADWAYS .....	2
EARTH EXCAVATION (SPECIAL) .....	3
PCC SIDEWALK 4 INCH, SPECIAL .....	4
PCC SIDEWALK 5 INCH, SPECIAL .....	5
CURB REMOVAL AND REPLACEMENT .....	6
SIDEWALK REMOVAL, (SPECIAL) .....	7
BRICK PAVER REMOVAL AND REPLACEMENT.....	8-9
BRICK PAVER REMOVAL .....	10
6 INCH DIAMETER PIPE BOLLARD, CONCRETE FILLED .....	11-12
BUS SHELTER .....	13-27
PARKWAY RESTORATION.....	28-29
STEP DOWN TRANSFORMER .....	30
COURSE AGGREGATE FOR HMA (D-1) .....	31-33
FINE AGGREGATE FOR HMA (D-1) .....	34
STATUS OF UTILITIES TO BE ADJUSTED (D-1).....	35
TEMPERATURE CONTROL FOR CONCRETE PLACEMENT (D-1).....	36
RECLAIMED ASPHALT PAVEMENT (RAP)(BMPR) .....	37-45
RECLAIMED ASPHALT SHINGLES (RAS)(BMPR).....	46-54
GENERAL ELECTRICAL REQUIREMENTS.....	55-57
UNDERGROUND RACEWAYS .....	58
MAINTENANCE OF LIGHTING SYSTEMS .....	59-62
COOPERATION WITH UTILITIES (LR 105)	63-65
INSURANCE (LR 107-4)	66
	112-114

WIRE AND CABLE

Revised 5-26-2011

## Wire and Cable

Effective: January 1, 2007

Revise the second sentence of the first paragraph of Article 1066.02(a) to read:

"The cable shall be rated at a minimum of 90°C dry and 75°C wet and shall be suitable for installation in wet and dry locations, and shall be resistant to oils and chemicals."

Revise the second paragraph of Article 1066.02(b) to read:

"Uncoated conductors shall be according to ASTM B3, ICEA S-95-658/NEMA WC70, and UL Standard 44. Coated conductors shall be according to ASTM B 33, ASTM B 8, ICEA S-95-658/NEMA WC70 and UL Standard 44."

Revise the third paragraph of Article 1066.02(b) to read:

"All conductors shall be stranded. Stranding meeting ASTM B 8, ICEA S-95-658/NEMA WC70 and UL Standard 44. Uncoated conductors meeting ASTM B 3, ICEA S-95-658/NEMA WC70 and UL Standard 44."

Revise the first sentence of Article 1066.03(a)(1) to read:

"General. Cable insulation designated as XLP shall incorporate cross-linked polyethylene (XLP) insulation as specified and shall meet or exceed the requirements of ICEA S-95-658, NEMA WC70, U.L. Standard 44."

Add the following to Article 1066.03(a)(1) of the Standard Specifications:

"The cable shall be rated 600 volts and shall be UL Listed Type RHH/RHW/USE."

Revise the Aerial Electric Cable Properties table of Article 1066.03(a)(3) to read:

Aerial Electric Cable Properties

Phase Conductor		Messenger wire		
Size AWG	Stranding	Average Insulation	Minimum Size	Stranding

		Thickness		AWG	
		mm	mils		
6	7	1.1	(45)	6	6/1
4	7	1.1	(45)	4	6/1
2	7	1.1	(45)	2	6/1
1/0	19	1.5	(60)	1/0	6/1
2/0	19	1.5	(60)	2/0	6/1
3/0	19	1.5	(60)	3/0	6/1
4/0	19	1.5	(60)	4/0	6/1

Revise the first paragraph of Article 1066.03(b) to read:

"EPR Insulation. Cable insulation shall incorporate ethylene propylene rubber (EPR) as specified and the insulation shall meet or exceed the requirements of ICEA S-95-658, NEMA Standard Publication No. WC70, and U.L. Standard 44, as applicable."

Add the following to Article 1066.03(b) of the Standard Specifications:

"Cable sized No. 2 AWG and smaller shall be U.L. listed Type RHH/RHW and may be Type RHH/RHW/USE. Cable sized larger than No. 2 AWG shall be U.L. listed Type RHH/RHW/USE."

Revise Article 1066.04 to read:

"Aerial Cable Assembly. The aerial cable shall be an assembly of insulated aluminum conductors according to Section 1066.02 and 1066.03. Unless otherwise indicated, the cable assembly shall be composed of three insulated conductors and a steel reinforced bare aluminum conductor (ACSR) to be used as the ground conductor. Unless otherwise indicated, the code word designation of this cable assembly is "Palomino". The steel reinforced aluminum conductor shall conform to ASTM B-232. The cable shall be assembled according to ANSI/ICEA S-76-474."

Revise the second paragraph of Article 1066.05 to read:

"The tape shall have reinforced metallic detection capabilities consisting of a woven reinforced polyethylene tape with a metallic core or backing."

Revise Article 1066.08 to read:

"Electrical Tape. Electrical tape shall be all weather vinyl plastic tape resistant to abrasion, puncture, flame, oil, acids, alkalies, and weathering, conforming to Federal Specification MIL-I-24391, ASTM D1000 and shall be listed under UL 510 Standard. Thickness shall not be less than 0.215 mm (8.5 mils) and width shall not be less than 20 mm (3/4-inch)."