



*6AWG UD=UNIT DUCT, 600V, 2-1C NO.6, 1/C NO.6 GROUND, (XLP-TYPE USE), 1" DIA. POLYETHYLENE AND ELECTRIC CABLE IN CONDUIT, 600V (XLP-TYPE USE) 3-1/C NO. 6
 *4AWG UD=UNIT DUCT, 600V, 2-1C NO.4, 1/C NO.4 GROUND, (XLP-TYPE USE), 1" DIA. POLYETHYLENE
 *2AWG UD=UNIT DUCT, 600V, 2-1C NO.2, 1/C NO.2 GROUND, (XLP-TYPE USE), 1 1/4" DIA.POLYETHYLENE

--- EXISTING
 ——— PROPOSED

FILE NAME =	USER NAME = prestonme	DESIGNED -	REVISED -
es:\pwork\puidot\prestonme\dms65337\d876e09-sh1-lightdgn		DRAWN -	REVISED -
PLOT SCALE = 50,0000 "/ IN.		CHECKED -	REVISED -
PLOT DATE = 6/25/2010		DATE -	REVISED -

STATE OF ILLINOIS
 DEPARTMENT OF TRANSPORTATION

WIRING DIAGRAM 2 OF 9

SCALE: _____ SHEET NO. ___ OF ___ SHEETS STA. _____ TO STA. _____

F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
255	DIST. 8 LIGHT POLE 2009-1		146	139
CONTRACT NO. 76CQ9				

MADISON, MONROE & ST. CLAIR