



*6AWG UD=UNIT DUCT, 600V, 2-1C NO.6, 1/C NO.6 GROUND, (XLP-TYPE USE), 1" DIA. POLYETHYLENE AND ELECTRIC CABLE IN CONDUIT, 600V (XLP-TYPE USE) 3-1/C NO. 6

*4AWG UD=UNIT DUCT, 600V, 2-1C NO.4, 1/C NO.4 GROUND, (XLP-TYPE USE), 1" DIA. POLYETHYLENE

*2AWG UD=UNIT DUCT, 600V, 2-1C NO.2, 1/C NO.2 GROUND, (XLP-TYPE USE), 1 1/4" DIA.POLYETHYLENE

--- EXISTING

— PROPOSED

FILE NAME =	USER NAME = prestonme	DESIGNED -	REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	WIRING DIAGRAM 9 OF 9	F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.	
ci:\pwwork\pwwork\prestonme\dms65337\0870c09-shr-light.dgn	PLOT SCALE = 50.0000' / IN.	DRAWN -	REVISED -			255 DIST. 8 LIGHT POLE 2009-1			146	146	
PLOT DATE = 6/8/2010	DATE -	CHECKED -	REVISED -			CONTRACT NO. 76C09					
		DATE -	REVISED -			MADISON, MONROE & ST. CLAIR					