



LEGEND

	EX REIL CABLE
	EX PAPI CABLE
	EX RUNWAY OR TAXIWAY CABLE
	PR ELECTRICAL DUCT
	PR 1/C #8 5 KV UG CABLE IN UD
	PR 2/C #8 5 KV UG CABLE IN UD
	PR 3/C (#4 OR #6 AS CALLED OUT) 600 V UG CABLE IN UD
	EX RUNWAY OR TAXIWAY LIGHT
	PR STAKE MOUNTED RUNWAY LIGHT
	PR STAKE MOUNTED LED TAXIWAY LIGHT
	EX TAXI GUIDANCE SIGN
	PR TAXI GUIDANCE SIGN
	PR ELECTRICAL HANDHOLE
	EX REIL OR PAPI
	EX WIND TEE
	EX WIND CONE
	PR WIND CONE

NOTES:

PROPOSED TAXIWAY LIGHTS TO BE SPACED 10' FROM TAXIWAY PAVEMENT EDGE.

PROPOSED TAXIWAY GUIDANCE SIGNS TO BE A MINIMUM 15' FROM TAXIWAY PAVEMENT EDGE.

ALL CONCRETE ENCASED DUCTS MUST BE A MINIMUM OF 24" DEPTH FROM TOP OF CONCRETE TO GROUND SURFACE.

ALL DUCTS NOT ENCASED MUST BE A MINIMUM OF 24" DEPTH FROM TOP OF DUCT TO GROUND SURFACE

TO ALLOW CLEARANCE FOR UNIT DUCT SERIES CABLE, CONTRACTOR SHALL USE CAUTION WHEN CROSSING DUCT AREAS WITH OTHER CABLES

THE LOCATION, SIZE AND TYPE OF MATERIAL OF EXISTING UNDERGROUND AND/OR ABOVEGROUND UTILITIES INDICATED ON THE PLANS ARE NOT REPRESENTED AS BEING ACCURATE, SUFFICIENT OR COMPLETE. NEITHER THE OWNER NOR THE ENGINEER ASSUMES ANY RESPONSIBILITY WHATSOEVER IN RESPECT TO THE ACCURACY, COMPLETENESS OR SUFFICIENCY OF THE INFORMATION. THERE IS NO GUARANTEE, EITHER EXPRESSED OR IMPLIED, THAT THE LOCATIONS, SIZE AND TYPE OF MATERIAL OF EXISTING UNDERGROUND UTILITIES INDICATED ARE REPRESENTATIVE OF THOSE TO BE ENCOUNTERED IN CONSTRUCTION. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE ACTUAL LOCATION OF ALL SUCH FACILITIES, INCLUDING SERVICE CONNECTIONS TO UNDERGROUND UTILITIES. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE UTILITY COMPANIES OF HIS OPERATIONAL PLANS AND SHALL OBTAIN FROM THE RESPECTIVE UTILITY COMPANIES DETAILED INFORMATION AND ASSISTANCE RELATIVE TO THE LOCATION OF THEIR FACILITIES AND THE WORKING SCHEDULE OF THE COMPANIES FOR REMOVAL AND ADJUSTMENT WHERE REQUIRED. IN THE EVENT AN UNEXPECTED UTILITY INTERFERENCE IS ENCOUNTERED DURING CONSTRUCTION, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE UTILITY COMPANY OF JURISDICTION. THE OWNER'S REPRESENTATIVE AND/OR THE RESIDENT ENGINEER SHALL ALSO BE IMMEDIATELY NOTIFIED. ANY DAMAGES TO SUCH MAINS AND SERVICES SHALL BE RESTORED TO SERVICE AT ONCE AND PAID FOR BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE CONTRACT.

ALL UTILITY CABLES AND LINES SHALL BE LOCATED BY THE RESPECTIVE UTILITY. CONTACT JULIE (JOINT UTILITY LOCATION INFORMATION FOR EXCAVATORS) FOR UTILITY INFORMATION, PHONE: 1-800-892-0123. CONTACT THE FAA FOR ASSISTANCE IN LOCATING FAA CABLES AND UTILITIES. LOCATION OF FAA POWER, CONTROL, AND COMMUNICATION CABLES SHALL BE COORDINATED WITH AND/OR LOCATED BY THE FAA. ALSO CONTACT AIRPORT DIRECTOR/MANAGER AND AIRPORT PERSONNEL FOR ASSISTANCE IN LOCATING UNDERGROUND AIRPORT CABLES AND/OR UTILITIES. ALSO COORDINATE WORK WITH ALL ABOVEGROUND UTILITIES.

16 Jun 2014 1:03pm X:\2013\13215\13215 Base.dwg: Layout Tab '14ELEC'