

F.A. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
1569	02-00025-00-LT	COOK	14	3
STA.		TO STA.		
FED. ROAD DIST. NO.	ILLINOIS	FED. AID PROJECT		
CONTRACT NO. - 83711				



- EXISTING LIGHTING & ELECTRICAL SYSTEM**
- EXISTING ELECTRIC POWER 100 AMPERE-120V/240V; 1PHASE, 3 WIRE.
 - EXISTING LIGHTING HAS 3 WIRE CIRCUITRY 2 PHASE WIRES AND GROUND.
 - EXISTING LUMINAIRE HAS PHOTOCELL CONTROL AND OPERATES ON 240 VOLT.
 - THE EXISTING LIGHTING SYSTEM SHALL REMAIN IN OPERATION EVERY NIGHT, DUSK TO DAWN.
 - THE CONTRACTOR SHALL VERIFY IN FIELD THE EXISTING LIGHTING SYSTEM AND PREPARE SCHEMATIC CIRCUIT SKETCH OF CIRCUITRY. THE CONTRACTOR SHALL SUBMIT TO THE ENGINEER ONE COPY OF SCHEMATIC CIRCUIT SKETCH.

LEGEND

⊠ EXISTING CONTROLLER

⊠ EXISTING LIGHT POLE

THESE DETAILS OBTAIN FROM VILLAGE OF BEDFORD PARK FOR REFERENCE ONLY

Sunjoy Inc.
Area Lighting
212 TIMBERCREST DRIVE
SCHAUMBURG, ILLINOIS
60193-1572

ILLINOIS DEPARTMENT OF TRANSPORTATION
73rd STREET (FAU 1569)
VILLAGE OF BEDFORD PARK

EXISTING LIGHTING SYSTEM WITH CIRCUITRY

SCALE: 1"=NTS
DATE: 04-15-05

DRAWN BY: HMO
CHECKED BY: JS

REVISION 05-28-05
REVISION 05-21-05