



- NOTES:**
1. REFER TO DRAWINGS E-04 AND E-05 FOR ELECTRICAL SYMBOLS.
 2. REFER TO DRAWING E-06 FOR ELECTRICAL ABBREVIATIONS.
 3. REFER TO DRAWING E-59 THROUGH E-61 FOR ELECTRICAL EQUIPMENT FRONT ELEVATIONS.
 4. THE SERVICE ENTRANCE DISCONNECT SHALL BE A CIRCUIT BREAKER 1600A SENSOR RATING, 3 POLE, 600V WITH MICROLOGIC LSIG TRIP FUNCTION, SHALL BE MANUFACTURED BY SQUARE D, CAT. NO. RJF36160U44A OR APPROVED EQUAL.

PB Americas, Inc.
 230 WEST MONROE STREET,
 SUITE 900
 CHICAGO, IL. 60606

USER NAME = sharma	DESIGNED - A. CENTENO	REVISED -
FILE NAME = D:\6061-shr-elo-11.dgn	DRAWN - S. SHARMA	REVISED -
PLOT SCALE = NONE	CHECKED - M. INTATANO	REVISED -
PLOT DATE = 5/7/2009	DATE - MAY 8, 2009	REVISED -

**STATE OF ILLINOIS
 DEPARTMENT OF TRANSPORTATION**

**ELECTRICAL ONE LINE DIAGRAM
 EAST SIDE, SHEET 1**

SCALE: AS SHOWN SHEET NO. E-11 OF E-125 SHEETS STA. 379+06.09 TO STA. 382+45.28

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
389	2424-2B-R	COOK	398	282
FED. ROAD DIST. NO. 1 ILLINOIS FED. AID PROJECT			CONTRACT NO. 60D61	