



NOTES:

1. EQUIPMENT SHOWN SOLID IS PLATFORM MOUNTED AT ELEV. +6.0. EQUIPMENT DOTTED AT MEZZ. ELEV. +20.073. REFER TO DWG E-23 FOR DEMOLITION OF EQUIPMENT.
2. SHADED ZONE IS AREA TAKEN BY 5 CONDUIT TIERS UNDER MEZZ. FLOOR. REFER TO DWG E-23.
3. REFER TO DWG. E-04 AND E-05 FOR ELECTRICAL SYMBOLS.
4. REFER TO DWGS. E-66 AND E-67 FOR EXISTING CONDUIT AND WIRE SCHEDULES.
5. ALL ITEMS CROSSED BY HATCH LINES SHALL BE DEMOLISHED DURING STAGE 1 - ELECTRICAL DEMOLITION ON THE EASTBOUND SIDE OF THE BRIDGE. ALL ITEMS CROSSED BY CROSSHATCH LINES SHALL BE DEMOLISHED DURING STAGE 2 - ELECTRICAL DEMOLITION ON THE WESTBOUND SIDE OF THE BRIDGE.
6. DE-ENERGIZE, DISCONNECT AND REMOVE ALL STREET LIGHT POLE FEEDERS FROM THE STREET LIGHT ENCLOSURE. THE STREET LIGHT FEEDER AND ENCLOSURE TO REMAIN. REFER TO DWGS E26, E-35 AND E-56.
7. PRIOR TO DEMOLITION (STAGE 1), THE SOUTHWEST AND THE SOUTHEAST BRIDGE LEAVES WILL BE LOCKED IN THE OPEN POSITION PROVIDE TEMPORARY LIGHT AND POWER 24 HOURS PER DAY, 7 DAYS PER WEEK.
8. ALL ELECTRICAL EQUIPMENT WHICH ARE NO LONGER REQUIRED TO FUNCTION SHALL BE DE-ENERGIZED AND DISCONNECTED AT THE SOURCE OF THE POWER SUPPLY AND SHALL BE REMOVED AND COORDINATED WITH THE AUTHORITY.
9. AT ANY TIME THE CONTRACTOR SHALL NOT PERFORM ANY DEMOLITION WORK, RELOCATION, REPAIR OR REROUTING OF EXISTING CABLES, CONDUITS, JUNCTION BOXES OR ANY EQUIPMENT WITHOUT OBTAINING FULL CLEARANCE OF ANY ASBESTOS, AND/OR LEAD CONTAINING MATERIALS.
10. ALL ELECTRICAL EQUIPMENT BEING REMOVED SHALL BE DISPOSED OF AT NO ADDITIONAL COST TO THE AUTHORITY. ANY EQUIPMENT REQUIRED TO BE TURNED OVER TO THE AUTHORITY SHALL BE DELIVERED, THE EXACT LOCATION AND TIME OF DELIVERY WILL BE DETERMINED BY THE ENGINEER TWO WEEKS PRIOR TO THE EQUIPMENT BEING REMOVED.
11. FOLLOW THE SAME STEPS FOR STAGE 2 - DEMOLITION.
12. REFER TO DWGS. E-43 THRU E-46 FOR NEW POWER LAYOUTS.
13. CONDUITS C1, C2, C201, C203 AND C204 WILL BE DEMOLISHED DURING STAGE 2.
14. DE-ENERGIZE AND DISCONNECT THE ELECTRIC WATER HEATER AT THE SOURCE OF THE POWER SUPPLY. REMOVE AND REPLACE WITH THE NEW WATER HEATER, SHALL MATCH EXISTING ONE. CAP. 40 GAL AND SHALL BE 208V, 1 PHASE, 60HZ AND WITH NEW FEEDER AND DISCONNECT SWITCH AS SHOWN ON DWG. E-43.

PB Americas, Inc.
 230 WEST MONROE STREET,
 SUITE 900
 CHICAGO, IL. 60606

USER NAME = sharma
 FILE NAME = D:\6061-shr-elo-22.dgn
 PLOT SCALE = NONE
 PLOT DATE = 5/7/2009

DESIGNED - A. CENTENO
 DRAWN - S. SHARMA
 CHECKED - M. INTATANO
 DATE - MAY 8, 2009

REVISED -
 REVISED -
 REVISED -
 REVISED -

**STATE OF ILLINOIS
 DEPARTMENT OF TRANSPORTATION**

**ELECTRICAL DEMOLITION
 POWER AND CONTROL CONDUITS - WEST SIDE DOCK LEVEL - SHEET 1**

SCALE: AS SHOWN SHEET NO. E-22 OF E-125 SHEETS STA. 379+06.09 TO STA. 382+45.28

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
389	2424-28-R	COOK	398	293
				CONTRACT NO. 60D61
FED. ROAD DIST. NO. 1 ILLINOIS FED. AID PROJECT				