



NOTES:

1. REFER TO DRAWINGS E-04 AND E-05 FOR ELECTRICAL SYMBOLS.
2. REFER TO DRAWING E-06 FOR ELECTRICAL ABBREVIATIONS.
3. REFER TO DWGS. E-02 AND E-03 FOR GENERAL ELECTRICAL NOTES.
4. ELECTRICAL CONDUITS SHOWN DASHED ARE THE UNDER SIDEWALK SLAB BETWEEN STRINGERS.
5. ALL ELECTRICAL EQUIPMENT ENCLOSURES, PULL BOXES AND JUNCTION BOXES SHALL BE STAINLESS STEEL, TYPE 316 AND SHALL BE RATED NEMA 4X ABOVE OR UNDER THE VIADUCT.
6. ALL CONDUIT AND FITTINGS SHALL BE HOT-DIP GALVANIZED RIGID STEEL AND PVC COATED, AND POLYURETHANE COATED, ABOVE OR UNDER THE VIADUCT, UON.
7. THE CONTRACTOR SHALL FURNISH AND INSTALL ALL PULL BOXES REQUIRED TO FACILITATE THE ROUTING AND PULLING OF CONDUITS AND WIRES.
8. WHEREVER THE NUMBER OF CONDUIT BENDS EXCEED 180° AND NO SPLICE IS INVOLVED, CONTRACTOR SHALL USE MOGUL TYPE FITTINGS
9. REFER TO DRAWINGS E-68 AND E-69 FOR CONDUIT AND WIRE SCHEDULES.
10. REFER TO MECHANICAL DRAWING M-26 FOR EXACT LOCATIONS OF TRAFFIC AND BARRIER GATES.

PB Americas, Inc.
 230 WEST MONROE STREET,
 SUITE 900
 CHICAGO, IL. 60606

USER NAME = sharma
 FILE NAME = D:\68d81-shr-elo-41.dgn
 PLOT SCALE = NONE
 PLOT DATE = 5/7/2009

DESIGNED - A. CENTENO
 DRAWN - S. SHARMA
 CHECKED - M. INTATANO
 DATE - MAY 8, 2009

REVISED -
 REVISED -
 REVISED -
 REVISED -

**STATE OF ILLINOIS
 DEPARTMENT OF TRANSPORTATION**

**POWER PLAN
 EAST SIDE SIDEWALK LEVEL**
 SCALE: AS SHOWN | SHEET NO. E-41 OF E-125 SHEETS | STA. 379+06.09 TO STA. 382+45.28

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
389	2424-2B-R	COOK	398	312
CONTRACT NO. 60D61				
FED. ROAD DIST. NO. 1 ILLINOIS FED. AID PROJECT				