



NOTES:

1. REFER TO DRAWINGS E-04 AND E-05 FOR ELECTRICAL SYMBOLS.
2. REFER TO DRAWING E-06 FOR ELECTRICAL ABBREVIATIONS.
3. REFER TO DWGS. E-02 AND E-03 FOR GENERAL ELECTRICAL NOTES.
4. ALL ELECTRICAL EQUIPMENT ENCLOSURES, PULL BOXES, JUNCTION BOXES AND TERMINAL CABINETS SHALL BE HOT-DIP GALVANIZED STEEL AND SHALL BE RATED NEMA 1 OR 12 IN THE MEZZANINE AREA.
5. ALL CONDUIT AND FITTINGS SHALL BE HOT-DIP GALVANIZED RIGID STEEL IN THE MEZZANINE AREA.
6. THE CONTRACTOR SHALL FURNISH AND INSTALL ALL PULL BOXES REQUIRED TO FACILITATE THE ROUTING AND PULLING OF CONDUITS AND WIRES.
7. WHEREVER THE NUMBER OF CONDUIT BENDS EXCEED 180° AND NO SPLICE IS INVOLVED, CONTRACTOR SHALL USE MOGUL TYPE FITTINGS.
8. REFER TO DRAWINGS E-68 AND E-69 FOR CONDUIT AND WIRE SCHEDULES.
9. REFER TO DRAWING E-60 FOR ELECTRICAL EQUIPMENT ELEVATION.

POWER PLAN
1/4"=1'-0"

PB Americas, Inc. 230 WEST MONROE STREET, SUITE 900 CHICAGO, IL. 60606	USER NAME = sharma FILE NAME = D:\60d61-sht-elo-44.dgn PLOT SCALE = NONE PLOT DATE = 5/7/2009	DESIGNED - A. CENTENO DRAWN - S. SHARMA CHECKED - M. INTATANO DATE - MAY 8, 2009	REVISED - REVISED - REVISED - REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	POWER PLAN WEST SIDE MEZZANINE LEVEL		F.A.P. RTE. = 389 SECTION = 2424-2B-R COUNTY = COOK TOTAL SHEETS = 398 SHEET NO. = 315
	SCALE: AS SHOWN SHEET NO. E-44 OF E-125 SHEETS STA. 379+06.09 TO STA. 382+45.28						
	CONTRACT NO. 60D61						
	FED. ROAD DIST. NO. 1 ILLINOIS FED. AID PROJECT						