
STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION



NEW SLAB

NOTES

Detail I - With Bar Splicer or Couplers:

Connect one (1) 1"x7"x10" steel P to the top layer of couplers with $2^{-5}8$ " ϕ bolts screwed to coupler at approximate Q of each barrier panel.

Detail II - With Extended Reinforcement Bars:

Connect one (1) 1"x7"x 10" steel f_c^0 to the concrete slab or concrete wearing surface with $2^{-5}g''$ ϕ Expansion Anchors or cast in place inserts spaced between the top layer of reinforcement at approximate f_c^0 of each barrier panel.

Cost of anchorage is included with Temporary Concrete Barrier.
The 1" x 7" x 10" plate shall not be removed until stage II construction forms and all reinforcement bars are in place and the concrete is ready to be placed.

SECTIONS THRU SLAB OR DECK BEAM


EXISTING SLAB


*** Dimension shown is minimum required embedment into concrete.

If hot-mix asphalt wearing surface is present, minimum embedment shall be in addition to wearing surface depth.

**** If existing deck beam is to remain in place after stage construction,

**** If existing deck beam is to remain in place after stage construction, embedment shall only be into wearing surface and not into existing deck beam concrete.





EXISTING DECK BEAM

Top bars Detail I spacing 3" 3" Detail II

Let a spacing 5" Detail II

Let a spacing 7" A Holes 7"

STEEL RETAINER P 1" x 7" x 10"

* Required only with Detail II

** Wood blocks may be omitted when required to provide minimum stage traffic lane width. When the wood blocks are omitted, the concrete barrier shall be in direct contact with the steel retainer plate.

"W" = Top bars spacing + 4"

DESIGNED - ASP CHECKED - WSP DRAWN - BEM CHECKED - ASP

DLZ 85 W. Algonquin Rd. Ste. 220
Arlington Heights II 60005
(847)-640-0840

TEMPORARY	CONCRETE	BARRIER
STRUCTURE	NUMBER	016-0610

								
SHEET NO.4 OF	F.A RTE.	SECTION		COUNTY	TOTAL SHEETS		SHEE NO.	
	94	0101	0101 . 8B			139		80
42 SHEETS					CONTRACT	NO.	60	C18
			ILLINOIS	FED. A	D PROJECT			