



NOTE: HOLE FOR FOUNDATION MUST BE AUGURED IN UNDISTURBED SOIL

CODE	COMMODITY	SIZE	QUANTITY
05-3267-2940	REDI-MIX CONCRETE	CU. YD.	0.82 OR 1.05
09-4001	ELBOW, LARGE RADIUS	2" x 2-1/2" x 3" x 4"	VARIES
31-8180-2200	ANCHOR ROD	1-1/4" x 60"	4
05-5054-6910	RE-BAR CAGE	20" x 6" (10" x 8")	1
09-7795-3200	GROUND ROD	3/4" x 12'-0"	1
09-2636-3240	GROUND ROD CLAMP	3/4"	1
09-2092	GROUND BUSHING	2" x 2-1/2" x 3" OR 4"	VARIES

8/21/02	SUPERCEDES DWS #816 DRAWN 4/21/81	REVISION
DATE		
FOUNDATION FOR 34'-6" ARTERIAL STREET LIGHT OR TRAFFIC SIGNAL POLE - 3 OR 7 GAUGE WITH 15" BOLT CIRCLE		
CITY OF CHICAGO		
DEPT. OF STREETS AND SANITATION		
MUNICIPAL ENGINEERING		
DIVISION OF ELECTRICAL ENGINEERING		
DRAWN BY	DATE	ENGINEER
B. GARNSEY	8/21/02	B. GARNSEY
ELECTRICAL ENGINEER		
818		
SCALE	NONE	8/21/02

