



Cable splices according to Art 1066.06 with compression connectors appropriately taped.

Stainless steel standard grade wire cloth, 6x6 (1/4") mesh or less with #16 gauge (0.062") diameter or heavier wire.

Attach with 1/2" stainless steel banding or tie back on itself with stainless steel wire ties. Finished installation must prevent rodent entry.

Pole ground lug  
Wireway window in pole foundation

2-1/2" #10 XLP-USE cable to each luminaire

For each luminaire use 2 pole fused quick disconnect. For receptacle circuit (not shown) use 2 pole fuseholder with solid neutral.

Pole base plate  
1" leveling nuts

## WIRING DETAIL

NO SCALE

### GENERAL NOTES

All taped splices shall use 2 layers of electrical tape over 3 layers of rubber tape as required by the Standard Specifications. Coat the finished taped splice with bonding compound.

All cable splices shall be taped unless another method has been specifically approved by the Engineer.

For example purposes the pole is shown on an anchor base. If the pole is required to be set on a breakaway base, consult the Standard Specifications.

All dimensions are in millimeters (inches) unless otherwise shown.

CONTRACT: 72D80  
SHEET 14 OF 16

DATE	REVISIONS
7/31/08	Updated

POLE HANDHOLE WIRING