



NOTES:

- LFNC shall be resistant to oil, water, chemical, and UV and shall be suitable for outdoor, direct bury, and extreme cold use according to NEC Art. 356.
- LFNC length shall not exceed 6'.
- Junction box at west abutment shall be sized per NEC, but shall not be smaller than 18" x 12" x 6".
- Two (2) Galv. steel conduits, PVC coated are needed at west abutment.

All dimensions are in millimeters (Inches) unless otherwise shown.

FILE NAME = S:\Projects\403-00072-57-70\dgn\FayetteLighting.dgn	USER NAME = betay	DESIGNED -	REVISED - 7-31-08 Updated	<b>STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION</b>	<b>CONDUIT EXITING BRIDGE PARAPET, FAYETTE AVENUE</b>		F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
PLOT SCALE = 40,0000' / IN.	DRAWN -	REVISED -	57/70				(25-31)-6	EFFINGHAM	839	285	
PLOT DATE = 6/23/2010	CHECKED -	REVISED -	CONTRACT NO. 74293								
DATE -	REVISED -	ILLINOIS FED. AID PROJECT									
					SCALE:	SHEET NO. 23 OF 24 SHEETS	STA.	TO STA.			