

DETAIL 1

NOTES:
1. NEW PEDESTRIAN WALKWAY BRIDGE LIGHTING CIRCUIT SHALL BE CONNECTED TO NEW CONTROLLER "A3". REFER TO PROPOSED ELECTRICAL SHEET 2 OF 7 FOR LOCATION.
2. PROVIDE WATERTIGHT SEAL CONNECTION AT JUNCTION BOX.


2" RGS CONDUIT, WITH 2-1/C NO.10 AWG, 1-1/C NO. 10 AWG GROUND. (TYPICAL)



REVISIONS	
NAME	DATE

INTERSECTION IMPROVEMENT
WASHINGTON STREET - 75th STREET
PROPOSED ELECTRICAL PLAN
PEDESTRIAN WALKWAY
SHEET 1 OF 1

CONSULTANT
TYLIN INTERNATIONAL

City of  **Naperville**

DRAWN: JRH	SHEET NO.
CHECKED: FO	
APPROVED: DEM	
DATE: 04/11/08	
SCALE: 1" = 0'-0"	
JOB NO.: P-91-494-00	PROJECT NO.: CMM-7003 (983)