



CABLE / CONDUIT SCHEDULE

- (XLP-TYPE USE), 3/4" DIA. POLYETHYLENE
- B UNIT DUCT, 600V, 2-1C NO. 6, 1/C NO. 8 GROUND, (XLP-TYPE USE), 1" DIA. POLYETHYLENE
- © UNIT DUCT, 600V, 2-1C NO. 4, 1/C NO. 6 GROUND, (XLP-TYPE USE), 1" DIA. POLYETHYLENE
- © ELECTRIC CABLE IN CONDUIT, 600V, (XLP-TYPE USE), 2-IC NO. 8, 1/C NO. 8 GROUND IN 2" DIA. PVC CONDUIT EMBEDDED IN STRUCTURE
- ELECTRIC CABLE IN CONDUIT, 600V, (XLP-TYPE USE), 2-1C NO. 6, 1/C NO. 8 GROUND IN 2" DIA. PVC CONDUIT EMBEDDED IN STRUCTURE
- ELECTRIC CABLE IN CONDUIT, 600V, (XLP-TYPE USE), 2-1C NO, 4, 1/C NO, 6 GROUND IN 2" DIA. PVC CONDUIT EMBEDDED IN STRUCTURE
- ELECTRIC CABLE IN CONDUIT, 600V, (XLP-TYPE USE), 2-1C NO. 6, 2-1/C NO. 4, 1/C NO. 6 GROUND IN 2" DIA. PVC CONDUIT EMBEDDED IN STRUCTURE
- UNIT DUCT, 600V, 2-1C NO. 2, 1/C NO. 4 GROUND, (XLP-TYPE USE), 1 1/4" DIA. POLYETHYLENE

⚠ LIGHT POLE FOUNDATION

LIGHT POLE FOUNDATION (SPECIAL)

0 50' 100

L-22

0

PROPOSED LIGHTING UNIT, 45 FT ALUMINUM

POLE, TWIN 8 FT DAVIT ARM, (2) 400W HPS

PROPOSED LIGHTING UNIT, 50 FT ALUMINUM POLE, 15 FT DAVIT ARM, 400W HPS LUMINAIRE, M-C-3

LUMINAIRES, M-C-3

SERVICE INSTALLATION

EXISTING LIGHTING CONTROLLER

PROPOSED LIGHTING CONTROLLER

 \boxtimes_{E}

 \blacksquare

FILE NAME =

\projects*-80072.57-78\dgn\S TriLv\pnk.stl.dgn

PROPOSED LIGHTING UNIT, 50 FT ALUMINUM POLE, TWIN 15 FT DAVIT ARM, (2) 400W HPS

----- PROPOSED UNIT DUCT, SIZE AS NOTED

JUNCTION BOX, STAINLESS STEEL, ATTACHED TO STRUCTURE OR EMBEDDED IN STRUCTURE, SIZE AS NOTED

PROPOSED UNDERGROUND COILABLE NON-METALLIC CONDUIT, SIZE AS NOTED

STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION

PROPOSED LIGHTING, RAMP F NORTH TRI LEVEL

SCALE: 1"=50" SHEET NO. 22 OF 35 SHEETS STA. 13+00.00 TO STA. 24+00.00