



Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

September 14, 2007

SUBJECT: Project TE-D8(113)
Section 06-00026-01-MS (Hartford)
Madison County
Contract No. 97301
Item 67
September 21, 2007 Letting
Addendum (A)

TO PROSPECTIVE BIDDERS:

Due to clarify information necessary to revise the following:

Proposal – Added answers to questions from Pre-Bid meeting.

Prime contractors must utilize the enclosed material when preparing their bid and must include any Schedule of Prices changes in their bidding proposal.

Bidders using computer-generated bids are cautioned to reflect any and all Schedule of Prices changes, if involved, into their computer programs.

Very truly yours,

Eric Harm
Interim Engineer of Design and Environment

A handwritten signature in cursive script, reading "Ted B. Walschleger" followed by the initials "AE." to the right.

By: Ted B. Walschleger
Engineer of Project Development
and Implementation

INDEX OF SPECIAL PROVISIONS

<u>TITLE</u>	<u>PAGE</u>
PROJECT LOCATION	1
PROJECT DESCRIPTION	1
SUPPLEMENTAL SPECIFICATIONS FOR UTILITY WORK	1
COORDINATION WITH OTHER PROFESSIONAL DISCIPLINES	1
TRAFFIC PROHIBITION ON COMPLETED CONSTRUCTION	1
JOINT UTILITY LOCATING INFORMATION FOR EXCAVATORS (JULIE)	2
SHORING, SHEETING AND BRACING	2
CONSTRUCTION AND MAINTENANCE SIGNS	3
TRAFFIC CONTROL PLAN	3
TRAFFIC CONTROL AND PROTECTION	4
WATERLINE / SEWER LINE CROSSINGS	4
SEEDING, CLASS 1 (MODIFIED)	5
PAVED DITCH (SPECIAL)	6
CONSTRUCTION ACCESS	6
FUSION WELDED PIPE, 8" HIGH DENSITY POLYETHYLENE, SDR-11, 160 PSI	7
MANHOLES (LEAKAGE TESTING)	8
MANHOLES, TYPE A, 4' DIAMETER, WATERPROOF FRAME & BOLTED LID	9
OUTFALL STRUCTURE	9
FIRE HYDRANT COMPLETE	9
DUCTILE IRON WATER MAIN FITTINGS	10
CONSTRUCTION STAKING	11
PLAZA DRAINAGE SYSTEM	12
REMOVE EXISTING CAP	13
REMOVE EXISTING PLUG	14
WATER MAIN TRACER WIRE	14
WATER METER	15
CONCRETE PAVERS	15
BUILDING	15
STATUS OF UTILITIES	15
MONTHLY LABOR SUMMARY	16
SwPPP	17
NOTICE OF INTENT	24
LEVEE DISTRICT LICENSE	25a.
PRE-BID MEETING	25b.

Revised 9-14-07

Project TE-D8(113)
Section 06-00026-01-MS (Hartford)
Madison County
Contract No. 97301
Item 67
September 21, 2007 Letting
Addendum (A)

The roof hatch is existing in the North tower. Only that work marked "NIC" is not included. All other work is required.

The foundation for the walkway slab is shown as being required for Section 06-00026-01-MS (Welcome Center).

The walkway leading to the towers is included in Section 03-00026-00-PK (Restrooms).

According to Section 01501, Part A, paragraph 1.3, sub-paragraph B of the Special Provisions, temporary electricity is the responsibility of the contractor.

Earth Excavation is specific for each phase of work and presumes that Section 03-00026-00-PK is performed prior to Section 06-00026-01-MS. Any other sequence will cause a revision of the plans and quantities for both sections.

Added 9-14-07

256,