| F.A. RTE. | SECTION | COUNTY | TOTAL SHEETS | SHEET NO. |
|---|---|---|---|---|
| | 06-00026-01-MS | MADISON | 43 | 43 |

FEDERAL AID PROJECT

EXISTING PANEL

PANELBOARD - LP
MOUNTING - SURFACE
A.I.C. RATING - 22,000
VOLTAGE 208 / 120
PHASE 3
WIRE 4
AMP BUS -
AMP MCB 100
AMP MLO 100
SPECIAL FEATURES -

| LOAD DESCRIPTION | LOAD (VA) LIGHT | RECEP. | HVAC | MISC. | BREAKER AMP | POLES | CIRCUIT | 3 PH A | B | C | CIRCUIT | BREAKER POLES | AMP | LOAD (VA) LIGHT | RECEP. | HVAC | MISC. | LOAD DESCRIPTION |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| NW FLOODLIGHT | 1950 | | | | 20* | 2 | 1 | | | | 2 | 1 | 20 | 912 | | | | EXTERIOR ENTRY LIGHTING |
| | 1050 | | | | | | 3 | | | | 4 | 1 | 20* | 742 | | | | EXTERIOR ENTRY LIGHTING |
| SW FLOODLIGHT | 1050 | | | | 20* | 2 | 5 | | | | 6 | 1 | 20 | 525 | | | | PLAZA LIGHTING SOUTH |
| | 1550 | | | | | | 7 | | | | 8 | 1 | 20 | 625 | | | | PLAZA LIGHTING NORTH |
| SE FLOODLIGHT | 1050 | | | | 20* | 2 | 9 | | | | 10 | 1 | 20* | 1000 | | | | FOUNTAIN LIGHTING |
| | 1950 | | | | | | 11 | | | | 12 | 2 | 25 | 500 | | | | PARKING LOT LIGHTING NORTH |
| NE FLOODLIGHT | 1550 | | | | 20* | 2 | 13 | | | | 14 | | | 500 | | | | |
| | 1650 | | | | | | 15 | | | | 16 | 1 | 20 | 1000 | | | | WATER WALL FLOODLIGHTS |
| PARKING LOT LIGHTING NORTH | 1500 | | | | 20 | 2 | 17 | | | | 18 | 1 | 20 | 1000 | | | | WATER WALL FLOODLIGHTS |
| | 1500 | | | | | | 19 | | | | 20 | 1 | 20 | 1000 | | | | WATER WALL FLOODLIGHTS |
| PARKING LOT LIGHTING SOUTH | 750 | | | | 20* | 2 | 21 | | | | 22 | 1 | 20 | 1000 | | | | WATER WALL FLOODLIGHTS |
| | 750 | | | | | | 23 | | | | 24 | 1 | 20 | | | | | SPARE |
| PARKING LOT LIGHTING SOUTH | 750 | | | | 20* | 2 | 25 | | | | 26 | 1 | 20 | | | | | SPARE |
| | 750 | | | | | | 27 | | | | 28 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 29 | | | | 30 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 31 | | | | 32 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 33 | | | | 34 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 35 | | | | 36 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 37 | | | | 38 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 39 | | | | 40 | 1 | 20 | | | | | SPARE |
| CONTACTORS C1 AND C2 | 100 | | | | 30 | 1 | 41 | | | | 42 | 1 | 20 | | | | | SPARE |

NOTES: ALL CIRCUIT BREAKERS SHOWN IN THIS PANEL SCHEDULE SHALL BE PROVIDED WITH THIS PANEL UNDER THE PHASE 2B CONTRACT. THE LOAD IDENTIFIED AT BREAKERS WITH AN ASTERISK (*) BEHIND THE AMPERAGE VALUE SHALL BE CONNECTED TO THIS PANEL AS PART OF THE PHASE 2A CONTRACT.

PANELBOARD - EP
MOUNTING - SURFACE
A.I.C. RATING - 22,000
VOLTAGE 208 / 120
PHASE 3
WIRE 4
AMP BUS 200
AMP MCB
AMP MLO 200
SPECIAL FEATURES -

| LOAD DESCRIPTION | LOAD (VA) LIGHT | RECEP. | HVAC | MISC. | BREAKER AMP | POLES | CIRCUIT | 3 PH A | B | C | CIRCUIT | BREAKER POLES | AMP | LOAD (VA) LIGHT | RECEP. | HVAC | MISC. | LOAD DESCRIPTION |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| ELEVATOR | | | | 9384 | | | 1 | | | | 2 | 1 | 20 | | | | 1200 | FIRE ALARM CONTROL PANEL |
| | | | | 9384 | 100 | 3 | 3 | | | | 4 | 1 | 20 | 1028 | | | | GROUND FLOOR LIGHTING - N |
| | | | | 9384 | | | 5 | | | | 6 | 1 | 20 | 1280 | | | | STAIR TOWER LIGHTING |
| ELEVATOR REMOTE MONITOR | | | | 1800 | 15 | 1 | 7 | | | | 8 | 1 | 20 | 1280 | | | | STAIR TOWER LIGHTING |
| ELEVATOR CAB LIGHTING | 500 | | | | 15 | 1 | 9 | | | | 10 | 1 | 20 | | 200 | | | INTERCOM POWER SUPPLY |
| ELEVATOR PIT & RECEPTACLE | 250 | | | | 20 | 1 | 11 | | | | 12 | 1 | 20 | | | | 750 | AV APPLIANCE POWER SUPPLY |
| ELEVATOR SUMP PUMP | | 200 | | | 20 | 1 | 13 | | | | 14 | 1 | 20 | | | | | SPARE |
| ELEVATOR MACHINE ROOM | 200 | 200 | | | 20 | 1 | 15 | | | | 16 | 1 | 20 | 1000 | | | | GROUND FLOOR LIGHTING - S |
| GEN. BATT CHARGER | | | | 1000 | 20 | 1 | 17 | | | | 18 | 1 | 20 | | | | | SPARE |
| GEN. JACKET HEATER | | | | 1000 | 20 | 1 | 19 | | | | 20 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 21 | | | | 22 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 23 | | | | 24 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 25 | | | | 26 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 27 | | | | 28 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 29 | | | | 30 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 31 | | | | 32 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 33 | | | | 34 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 35 | | | | 36 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 37 | | | | 38 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 39 | | | | 40 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 41 | | | | 42 | 1 | 20 | | | | | SPARE |

NOTES:

EXISTING PANEL

PANELBOARD - LRPS
MOUNTING - SURFACE
A.I.C. RATING - 22,000
VOLTAGE 208 / 120
PHASE 3
WIRE 4
AMP BUS 200
AMP MCB
AMP MLO 200
SPECIAL FEATURES -

| LOAD DESCRIPTION | LOAD (VA) LIGHT | RECEP. | HVAC | MISC. | BREAKER AMP | POLES | CIRCUIT | 3 PH A | B | C | CIRCUIT | BREAKER POLES | AMP | LOAD (VA) LIGHT | RECEP. | HVAC | MISC. | LOAD DESCRIPTION |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| LIGHTING | 770 | | | | 20 | 1 | 1 | | | | 2 | 1 | 20 | | 1000 | | | RECEPTACLES |
| CABINET UNIT HEATER CUH-2 | | | 2000 | | 25 | 3 | 3 | | | | 4 | 1 | 20 | | | 900 | | EF-2 AND DAMPER |
| | | | 2000 | | | | 5 | | | | 6 | 1 | 20 | | | | | SPARE |
| | | | 2000 | | | | 7 | | | | 8 | | | | | 1100 | | UNIT HEATER UH-2 |
| CABINET UNIT HEATER CUH-1 | | | 2000 | | 25 | 3 | 9 | | | | 10 | 3 | 20 | | | 1100 | | |
| | | | 2000 | | | | 11 | | | | 12 | | | | | 1100 | | |
| | | | 2000 | | | | 13 | | | | 14 | 1 | 20 | | 2300 | | | HAND DRYER |
| FOUNTAIN PUMPS FP-1 & FP-2 | | | | 5276 | 40* | 3 | 15 | | | | 16 | 1 | 20 | | 2300 | | | HAND DRYER |
| | | | | 5276 | | | 17 | | | | 18 | 1 | 20 | | | 400 | | MOTORIZED DAMPERS |
| | | | | 5276 | | | 19 | | | | 20 | 1 | 20 | | 1400 | | | RECEPTACLES |
| MOTORIZED DAMPER | | | | 1000 | 20* | 1 | 21 | | | | 22 | 1 | 20 | | 2300 | | | HAND DRYER |
| RECEPTACLES | | 800 | | | 20* | 1 | 23 | | | | 24 | 1 | 20 | | 2300 | | | HAND DRYER |
| SPARE | | | | | 20 | 1 | 25 | | | | 26 | | | | | 3333 | | UNIT HEATER UH-1 |
| SPARE | | | | | 20 | 1 | 27 | | | | 28 | 3 | 40* | | | 3333 | | |
| SPARE | | | | | 20 | 1 | 29 | | | | 30 | | | | | 3333 | | |
| PLATFORM RECEPTACLES | | 800 | | | 20* | 1 | 31 | | | | 32 | 1 | 20 | | 1000 | | | RECEPTACLE - FOOD WARMING |
| LIFE SAFETY LIGHTING | 360 | | | | 20** | 1 | 33 | | | | 34 | 1 | 20 | | 200 | | | RECEPTACLE AT POD UM |
| FIRE ALARM CONTROL PANEL | | | | 1000 | 20** | 1 | 35 | | | | 36 | 1 | 20 | | | | 3000 | WATER HEATER WH-1 |
| AV APPLIANCE PWR. SUPPLY | | | | 1000 | 20** | 1 | 37 | | | | 38 | 1 | 20 | | | | 3000 | |
| SPARE | | | | | 20 | 1 | 39 | | | | 40 | 1 | 20 | | | | 3000 | |
| FOUNTAIN CONTROL PANEL | | | | 500 | 20* | 1 | 41 | | | | 42 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 43 | | | | 44 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 45 | | | | 46 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 47 | | | | 48 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 49 | | | | 50 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 51 | | | | 52 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 53 | | | | 54 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 55 | | | | 56 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 57 | | | | 58 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 59 | | | | 60 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 61 | | | | 62 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 63 | | | | 64 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 65 | | | | 66 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 67 | | | | 68 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 69 | | | | 70 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 71 | | | | 72 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 73 | | | | 74 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 75 | | | | 76 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 77 | | | | 78 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 79 | | | | 80 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 81 | | | | 82 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 83 | | | | 84 | 1 | 20 | | | | | SPARE |

NOTES: ALL CIRCUIT BREAKER SHOWN IN THIS SCHEDULE SHALL BE PROVIDED UNDER THE PHASE 2B CONTRACT. WHERE A SINGLE ASTERISK APPEARS BY THE AMPERAGE VALUE OF A BREAKER, THE LOAD IDENTIFIED FOR THAT BREAKER SHALL BE CONNECTED TO THIS PANEL AS PART OF THE PHASE 2A CONTRACT. CIRCUIT BREAKERS WITH A DOUBLE ASTERISK (**) BEHIND THE AMPERAGE VALUE SHALL SERVE THE LOAD IDENTIFIED UNDER THE PHASE 2B CONTRACT AND SHALL BE RELABELED TO READ "SPARE" UNDER THE PHASE 2A CONTRACT.

PANELBOARD - LRPN
MOUNTING - SURFACE
A.I.C. RATING - 22,000
VOLTAGE 208 / 120
PHASE 3
WIRE 4
AMP BUS 200
AMP MCB
AMP MLO 200
SPECIAL FEATURES -

| LOAD DESCRIPTION | LOAD (VA) LIGHT | RECEP. | HVAC | MISC. | BREAKER AMP | POLES | CIRCUIT | 3 PH A | B | C | CIRCUIT | BREAKER POLES | AMP | LOAD (VA) LIGHT | RECEP. | HVAC | MISC. | LOAD DESCRIPTION |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| EF-1 AND DAMPER | | | 500 | | 20 | 1 | 1 | | | | 2 | 1 | 20 | 500 | | | | LIGHTING |
| UNIT HEATER UH-4 | | | 1100 | | 20 | 3 | 3 | | | | 4 | 1 | 20 | | 800 | | | RECEPTACLES |
| | | | 1100 | | | | 5 | | | | 6 | 1 | 20 | | 800 | | | RECEPTACLES |
| | | | 1100 | | | | 7 | | | | 8 | 1 | 20 | | | | 1500 | VENDING MACHINE |
| UNIT HEATER UH-3 | | | 1100 | | 20 | 3 | 9 | | | | 10 | 1 | 20 | | | | 1500 | VENDING MACHINE |
| | | | 1100 | | | | 11 | | | | 12 | 1 | 20 | | | | 1500 | VENDING MACHINE |
| | | | 1100 | | | | 13 | | | | 14 | 1 | 20 | | | | 1500 | VENDING MACHINE |
| CONDENSING UNIT CU-2 | | | 915 | | 20 | 2 | 15 | | | | 16 | 2 | 20 | | | 1246 | | CONDENSING UNIT CU-1 |
| | | | 915 | | | | 17 | | | | 18 | | | | | 1246 | | |
| RECEPTACLES | | 1200 | | | 20 | 1 | 19 | | | | 20 | | | | | 1272 | | AIR HANDLING UNIT AHU-1 |
| PHONE RECEPTACLE | | 400 | | | 20 | 1 | 21 | | | | 22 | 3 | 20 | | | 1272 | | |
| RECEPTACLE - FOOD WARMING | | 1000 | | | 20 | 1 | 23 | | | | 24 | | | | | 1272 | | |
| AIR CONDITIONER AC-1 | | | | | | 2 | 25 | | | | 26 | | | | | 5696 | | AIR HANDLING UNIT AHU-1 (HEAT) |
| | | | | | | | 27 | | | | 28 | 3 | 60 | | | 5696 | | |
| UH-3 | | | 3000 | | 30 | 1 | 29 | | | | 30 | | | | | 5666 | | |
| SUMP PUMP | | | 360 | | 20 | 1 | 31 | | | | 32 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 33 | | | | 34 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 35 | | | | 36 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 37 | | | | 38 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 39 | | | | 40 | 1 | 20 | | | | | SPARE |
| SPARE | | | | | 20 | 1 | 41 | | | | 42 | 1 | 20 | | | | | SPARE |

NOTES:

# EQUIPMENT DATA SCHEDULE

| LINE NO. | MARK | EQUIPMENT DESCRIPTION | EQUIPMENT LOCATION | FURN. BY (DIV.) | MOTOR OR EQUIPMENT DATA (1) HP/KW | VOLTS/ PHASE | FLA | INST. BY | CONN. BY | DISCONNECT SWITCH AT EQUIPMENT (2) TYPE | FURN. BY | INST. BY | CONN. BY | STARTER (3) TYPE | FURN. BY | INST. BY | CONN. BY | REMOTE CONTROLS (4) TYPE | FURN. BY | INST. BY | CONN. BY | (5) REMARKS |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | |
| 3 | UH-1 | UNIT HEATER | PUMP/MECH ROOM | 15 | 10 KW | 208/3 | 20.8 | 15 | 16 | NF | 15 | FAC | 16 | – | – | – | – | – | – | – | – | – |
| 4 | UH-2 | UNIT HEATER | JANITOR | 15 | 3.3 KW | 208/3 | 6.9 | 15 | 16 | NF | 15 | FAC | 16 | – | – | – | – | – | – | – | – | – |
| 5 | UH-3 | UNIT HEATER | ELEV MACHINE ROOM | 15 | 3.3 KW | 208/3 | 6.9 | 15 | 16 | NF | 15 | FAC | 16 | | | | | | | | | |
| 6 | UH-4 | UNIT HEATER | ELECTRICAL ROOM | 15 | 3.3 KW | 208/3 | 6.9 | 15 | 16 | NF | 15 | FAC | 16 | – | – | – | – | – | – | – | – | – |
| 7 | | | | | | | | | | | | | | | | | | | | | | |
| 8 | EF-1 | EXHAUST FAN | ELECTRICAL ROOM | 15 | 1/6 HP | 120/1 | – | 15 | 16 | NF | 15 | FAC | 16 | – | – | – | – | – | – | – | – | – |
| 9 | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | |
| 11 | FCU-1 | AIR HANDLING UNIT | CONCESSIONS | 15 | 3 HP | 208/3 | – | 15 | 16 | – | – | – | – | PWCP | 15 | FAC | 16 | – | – | – | – | – |
| 12 | FCU-1 | AIR HANDLING UNIT – HEAT | CONCESSIONS | 15 | 17 KW | 208/3 | – | 15 | 16 | NF | 16 | 16 | 16 | – | – | – | – | – | – | – | – | |
| 13 | | | | | | | | | | | | | | | | | | | | | | – |
| 14 | AC-1 | AIR CONDITIONER | ELEV MACHINE ROOM | 15 | – | 208/1 | .5 MCA | 15 | 16 | NF | 16 | 16 | 16 | – | – | – | – | – | | | | – |
| 15 | | | | | | | | | | | | | | | | | | | | | | |
| 16 | CU-1 | CONDENSING UNIT | AHU-1 | 15 | – | 208/3 | 15 MCA | 15 | 16 | NF,WP | 16 | 16 | 16 | – | – | – | – | – | – | – | – | – |
| 17 | CU-2 | CONDENSING UNIT | AC-1 | 15 | – | 208/1 | 11 MCA | 15 | 16 | NF,WP | 16 | 16 | 16 | – | – | – | – | – | – | – | – | – |
| 18 | | | | | | | | | | | | | | | | | | | | | | |
| 19 | | | | | | | | | | | | | | – | – | – | – | – | – | – | – | – |
| 20 | FP-1 | FOUNTAIN PUMP | – | 15 | 3 HP | 208/3 | – | 15 | 16 | NF | 16 | 16 | 16 | | | | | | | | | – |
| 21 | FP-2 | FOUNTAIN PUMP | – | 15 | 5 HP | 208/3 | – | 15 | 16 | NF | 16 | 16 | 16 | | | | | | | | | |
| 22 | | | | | | | | | | | | | | | | | | | | | | |
| 23 | WH-1 | WATER HEATER | – | 15 | 1.5 KW | 120/1 | – | 15 | 16 | S | 16 | 16 | 16 | – | – | – | – | – | – | – | – | |
| 24 | WH-2 | WATER HEATER | – | 15 | 3 KW | 120/1 | – | 15 | 16 | – | – | – | – | – | – | – | – | – | – | – | – | |
| 25 | SP-1 | SUMP PUMP | – | 15 | 1/2 HP | 120/1 | – | 15 | 16 | – | – | – | – | PWCP | 15 | 16 | 16 | – | – | – | – | |
| 26 | | | | | | | | | | | | | | | | | | | | | | |
| 27 | | | | | | | | | | | | | | | | | | | | | | |
| 28 | | | | | | | | | | | | | | | | | | | | | | |
| 29 | | | | | | | | | | | | | | | | | | | | | | |
| 30 | | | | | | | | | | | | | | | | | | | | | | |
| 31 | | | | | | | | | | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | | | |
| 34 | | | | | | | | | | | | | | | | | | | | | | |
| 35 | | | | | | | | | | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | | | | |
| 37 | | | | | | | | | | | | | | | | | | | | | | |
| 38 | | | | | | | | | | | | | | | | | | | | | | |
| 39 | | | | | | | | | | | | | | | | | | | | | | |
| 40 | | | | | | | | | | | | | | | | | | | | | | |

(1) HORSEPOWER (HP) IS SHOWN UNLESS KILLOWATTS (KW) ARE CALLED OUT.

(2) DISCONNECT TYPES:

CB = CIRCUIT BREAKER
F = FUSED
NF = NON FUSED
S = SWITCH (TOGGLE)
WP = WEATHERPROOF
FAC = FACTORY

(3) STARTER TYPES:

COMB = COMBINATION MAGNETIC FVNR WITH FUSIBLE DISCONNECT SWITCH
FVNR = FULL VOLTAGE NON-REVERSING
MAN = MANUAL STARTER
PWCP = PRE-WIRED CONTROL PANEL WITH INTEGRAL FVNR MAGNETIC STARTER AND DISCONNECT SWITCH
SDS = STAR DELTA STARTER
VSD = VARIABLE SPEED DRIVE
2S2W = 2 SPEED, 2 WINDING MAGNETIC STARTER

(4) REMOTE CONTROL:

BAS = BUILDING AUTOMATION SYSTEM
FAI = FIRE ALARM INTERLOCK
FST = FIRESTAT
INT = INTERLOCK WITH OTHER EQUIPMENT
RAD = REMOTE ALARM DEVICE
RPB = REMOTE START-STOP PUSH BUTTON
SSC = START-STOP CONTACT
TC = TIME CLOCK
TS = THERMOSTAT

(5) REMARKS:

1. EMERGENCY POWER.
2. 2 SPEED, 2 WINDING MOTOR.
3. STAND-BY UNIT.
4. VARIABLE SPEED DRIVE WITH PRE-WIRED STARTER AND INTEGRAL DISCONNECT SWITCH.

KAI
211 N. Broadway
Suite 1000
St. Louis, MO
63102
(314) 241-9180
FAX (314) 241-0325

PHASE 2A
LEWIS AND CLARK MEMORIAL TOWER
VILLAGE OF HARTFORD, ILLINOIS
HARTFORD, ILLINOIS 62049

SHEET TITLE:
EQUIPMENT DATA SCHEDULE

| REV. NO. | REMARKS | DATE |
|---|---|---|
| | | |

KENNEDY PROJECT NO
KAI# 10-02048

ISSUE DATE
12-JULY-05

SHEET NO
EA7-02

©2005 KENNEDY ASSOCIATES INCORPORATED

F:\2002\10 02\8\60005C\EA7 02.DWG | 7/2/2007 10:11:50 AM | Xref's: TB2435C3L | Images: none