



The Contractor shall install fuses in the service disconnect that are rated for the wire size in accordance with NEC requirements (60A fuses for #6 cable).

**FRONT** **SIDE**

**ELECTRIC SERVICE INSTALLATION**

- Size larger as needed.
- Or as directed by Utility Company.

FILE NAME =	USER NAME = tblank	DESIGNED -	REVISED -
... \ITS (DDT)\D468620-ITS-26.dgn		DRAWN -	REVISED -
		CHECKED -	REVISED -
		DATE -	REVISED -

**STATE OF ILLINOIS  
DEPARTMENT OF TRANSPORTATION**

**ELECTRIC SERVICE DETAIL FOR RELOCATED SIGN STRUCTURE  
I-74 & WASHINGTON BLACKTOP**

SCALE: NONE SHEET NO. 26 OF 50 SHEETS STA. TO STA.

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
74	90-[14R;(14HB-4,14,14HVB)BR]	TAZEWELL	2433	1690
CONTRACT NO. 68620			ILLINOIS FED. AID PROJECT	