



COMPLETE COMMODITY CODE NO. 05-6610-5310M

CODE NO.	MATERIALS	SIZE	QUAN.
(1) 05-6610-5310	PRE-CAST HANDHOLE	30"X36"	1
(2) 05-9075-5470	STONE 3/4" CRUSHED	BAG	5
(2) 05-5082-5330	SONO TUBE	30"	1
(2) 05-5082-5342	SONO TUBE	42"	1
(2) 05-3267-2940	CONC. REDI-MIX	CU. YD.	1/2
(2) 57-0770-0000	6" X 6" MESH	36"X10'	1
05-1452-9720	BRICK		24
02-4299-5524	FRAME MANHOLE	24"	1
02-4574-5040	COVER, MANHOLE	24"	1
09-7796-9312	GROUND ROD	3/4"X12'	1
09-2630-3240	GROUND CLAMP		1

- (1) PRE-CAST HANDHOLE SHALL INCLUDE CABLE HOOKS AND CONDUIT KNOCKOUTS.
- (2) THESE ITEMS ARE FOR POURED-IN-PLACE HANDHOLES ONLY.

CONSTRUCTION NOTES:

- 8" BED OF STONE FOR DRAINAGE.
- ALL METALLIC CONDUITS ENTERING HANDHOLE SHALL EXTEND MINIMUM 1" & MAXIMUM 3" INSIDE INNER WALL AND BE EQUIPPED WITH AN APPROVED TYPE OF THREADED GROUNDING BUSHING.

B	81-23-00	ADDED CABLE HOOKS PER COMMISSIONER HANPHY	(C/C/HD)
A	12-8-95	REDRAW (CAD)	MP.
	DATE	REVISION	
30" DIA. CONCRETE HANDHOLE			
CITY OF CHICAGO			
DEPT. OF STREET AND SANITATION DIVISION OF ELECTRICAL ENGINEERING			
DRAFTSMAN:	ENGINEER:	INSPECTOR:	TITLE:
M. PATTON	B. CARTER	DEBARTOLO	
SUPERVISING ENGINEER			UWG. NO.
ENGINEER OF ELECTRICITY			867
GENERAL SUPERVISOR OF ELECTRICITY			
DEPT. COMMISSIONER			
SIZE: 11"	SCALE: NONE	DATE: 12-8-95	

REVISIONS	
NAME	DATE

\c:\tech\it7\p40468\p40468.dwg\elec\4-crit\9094-contract\9013\0009091\000522.stp 02/02/2005 09:09:55 AM