



All steel rail elements shall be galvanized according to Article 509.05 of the Standard Specifications.

ELEVATION
(Inside Face)

SECTION A-A

SECTION B-B
(At Expansion Joint)

SECTION E-E

RAIL SPLICE

HANDRAIL SPLICE

BASE P
(Handrail)

VIEW C-C

VIEW D-D

BASE P

ANCHOR BOLT DETAILS

In lieu of the cast-in-place anchor device shown, the Contractor has the option of drilling and setting 5/8" φ anchor rods according to Article 509.06 of the Standard Specifications. Embedment shall be according to the manufacturer's specifications.

- Notes:
1. For fence post spacing on deck parapet see sheet S11
 2. For fence post spacing on Approach Slab parapet see sheet S13

BILL OF MATERIAL

Item	Unit	Quantity
Bridge Fence Railing	Foot	549

R-28

7-1-10 * Variable - See Plans (10'-0" Maximum Post Spacing)

HANDRAIL DETAIL