MATCH LINE STA. 172+00

MATCH LINE STA. 178+00

MATCH LINE STA. 183+00

ORNAMENTAL LIGHT UNIT, COMPLETE

GFCI 20 AMP DUPLEX RECEPTACLE

CONDUIT IN TRENCH, 2 1/2" DIA., GALVANIZED STEEL 69'

ORNAMENTAL LIGHT UNIT, COMPLETE

ORNAMENTAL LIGHT UNIT, COMPLETE

BOLLARDS

HAND HOLE (TYP)

PEDESTRIAN LIGHT POLE

COMBINATION CONCRETE CURB AND GUTTER, TYPE M (SPECIAL) TYP.

CONDUIT IN TRENCH, 2 1/2" DIA., GALVANIZED STEEL - 71'

ORNAMENTAL LIGHT UNIT, COMPLETE

BOLLARDS

℄ IL RTE 178 (RELOCATED)

PLANTERS (TYP.)

ORNAMENTAL LIGHT UNIT, COMPLETE

BOLLARDS

ORNAMENTAL LIGHT UNIT, COMPLETE

BOLLARDS

ORNAMENTAL LIGHT UNIT, COMPLETE

ORNAMENTAL LIGHT UNIT, COMPLETE

ORNAMENTAL LIGHT UNIT, COMPLETE

ORNAMENTAL LIGHT UNIT, COMPLETE

GFCI 20 AMP DUPLEX RECEPTACLE

ORNAMENTAL LIGHT UNIT, COMPLETE

ORNAMENTAL LIGHT UNIT, COMPLETE

CONDUIT IN TRENCH, 2 1/2" DIA., GALVANIZED STEEL 67'

CONDUIT IN TRENCH, 2 1/2" DIA., GALVANIZED STEEL 56'

NOTES:
1. 'TRENCH AND BACKFILL FOR ELECTRICAL WORK' SHALL BE PAID FOR SEPARATELY.
2. SEE SHEET 96 FOR FUTURE MONUMENT AND BRICK PAVER DETAILS (BY OTHERS).

CHURCH STREET

CANAL STREET

MILL STREET

CLARK STREET

EXISTING ELECTRICAL SERVICE AND METER PROPOSED LIGHTING CONTROLLER, BASE MOUNTED 240VOLT, 200AMP (DUAL)

IN GRADE FIXTURE FOR UPLIGHTING (8)

ORNAMENTAL LIGHT UNIT, COMPLETE

GFCI 20 AMP DUPLEX RECEPTACLE

CONDUIT IN TRENCH, 2 1/2" DIA., GALVANIZED STEEL 50'

IN GRADE FIXTURE FOR UPLIGHTING (6)

GFCI 20 AMP DUPLEX RECEPTACLE

FUTURE MONUMENT (BY OTHERS) NOTE 2

FUTURE MONUMENT (BY OTHERS) NOTE 2

BOLLARDS

BOLLARDS

BOLLARDS

CONNECT TO NEW BRIDGE LIGHTING

ORNAMENTAL LIGHT UNIT, COMPLETE

CONDUIT IN TRENCH, 4" DIA. GALVANIZED STEEL 56'

℄ IL RTE 178 (RELOCATED)

CONDUIT IN TRENCH, 2 1/2" DIA., GALVANIZED STEEL 43'

IN GRADE FIXTURE FOR UPLIGHTING (9)

CONDUIT EMBEDDED IN STRUCTURE, 2" DIA., GALVANIZED STEEL SEE BRIDGE PLANS FOR DETAILS

FUTURE MONUMENT (BY OTHERS) NOTE 2

GFCI 20 AMP DUPLEX RECEPTACLE

I & M CANAL

LEGEND

SEE SHEET 96 FOR STA./OFF. OF ALL ITEMS

- ● ORNAMENTAL LIGHT UNIT, COMPLETE & LIGHT POLE FOUNDATION (SPECIAL)
- ▣ IN GRADE FIXTURE FOR UPLIGHTING
- GFCI 20 AMP DUPLEX RECEPTACLE
- ○ BOLLARDS (SEE SCH. OF QUANTITIES FOR STA./OFF.)
- PROPOSED LIGHTING CIRCUIT
- PROPOSED LIGHTING CONTROLLER, BASE MOUNTED, 240VOLT, 200AMP (DUAL)
- PROPOSED HANDHOLE, COMPOSITE CONCRETE
- EXISTING CONTROLLER
- EXISTING HANDHOLE
- EXISTING FIRE HYDRANT
- EXISTING MANHOLE
- EXISTING POWER POLE
- Ⓐ UNIT DUCT, 600V, 2-1C NO.8, 1/C NO.8 GROUND, (XLP-TYPE USE), 3/4" DIA. POLYETHYLENE LIGHT ONLY (2 HOT)
- Ⓑ UNIT DUCT, 600V, 2-1C NO.8, 1/C NO.8 GROUND, (XLP-TYPE USE), 3/4" DIA. POLYETHYLENE REC ONLY (1 HOT, 1 NEUTRAL)
- Ⓒ UNIT DUCT, 600V, 5-1C NO.8, 1/C NO.8 GROUND, (XLP-TYPE USE), 1 1/4" DIA. POLYETHYLENE LIGHT AND RECEPTACLE (4 HOT, 1 NEUTRAL)
- Ⓓ ELECTRIC CABLE IN CONDUIT, 600V (XLP-TYPE USE) 1/C NO. 8

..\D366547-MOTIF18\DGN\..\D366547-BORDERLDGN..\D366547-MOTIF18\DGN..\D366547-SHT-LIGHT2.DGN
9-13-2012 14:25:06 BDNDNU0 \\FS-0044\VAR\VAULT\D TRANS.07\2202\20477-28\CIVIL\CAD\D66547\SHEET\D366547-SHT-LNDSCP2.DGN

FILE NAME = $FILE$	USER NAME = $USER$	DESIGNED - JM	REVISED -
		DRAWN - JB	REVISED -
TENG TENG & ASSOCIATES, INC. ENGINEERS/ARCHITECTS/PLANNERS CHICAGO, ILLINOIS	PLOT SCALE = $SCALE$	CHECKED - RS	REVISED -
	PLOT DATE = 9-13-2012	DATE - 08/10	REVISED -

STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION

SIDEWALK AND LANDSCAPE LIGHTING PLANS

SCALE: 1"=20' | SHEET NO. OF SHEETS | STA. | TO STA.

F.A.S. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
1279	6R,B	LA SALLE	190	95
		CONTRACT NO. 66547		
FED. ROAD DIST. NO.	ILLINOIS	FED. AID PROJECT		