



SEQUENCE OF CONSTRUCTION:

1. CLOSE EXISTING VALVE.
2. REMOVE EXISTING HYDRANT.
3. INSTALL HYDRANT EXTENSION AND NEW VALVE.
4. RELOCATE EXISTING HYDRANT.
5. OPEN EXISTING VALVE, REMOVE BOX.
6. BACKFILL.
7. FLUSH AND TEST FOR CHLORIDE RESIDUAL AND PROVIDE TEST.

ALL WORK TO BE DONE IN ACCORDANCE WITH ARTICLE 564 OF THE STANDARD SPECIFICATIONS. NEW VALVE AND BOX SHALL BE SAME MAKE AND MODEL AS EXISTING.

FIRE HYDRANT TO BE MOVED

ALL DIMENSIONS ARE IN INCHES (MILLIMETERS) UNLESS OTHERWISE SHOWN.

COMPANY NAME: SEC GROUP, INC.
 PROJECT CONTACT: J. MELNICHUK
 PROJECT LOCATION: BARTLETT
 DATE PLOTTED: 8/31/2009 4:27:44 PM
 FILE NAME: 090196-dst-14.dgn
 PLOT DRIVER: pdf.plt
 PEN TABLE: standard-trans.tbl



USER NAME = jmelhush	DESIGNED -	REVISED - R. SHAH 09-09-94
FILE NAME = 090196-dst-14.dgn	DRAWN -	REVISED - R. SHAH 10-25-94
PLOT SCALE =	CHECKED -	REVISED -
PLOT DATE = 8/31/2009	DATE -	REVISED -

STATE OF ILLINOIS
 DEPARTMENT OF TRANSPORTATION

FIRE HYDRANT TO BE MOVED

SCALE: SHEET NO. OF SHEETS STA. TO STA.

F.A.U. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
2537	09-00084-00-RS	COOK	53	40
BD-36		CONTRACT NO. 63274		
FED. ROAD DIST. NO. [ILLINOIS] FED. AID PROJECT ARA-9003 (345)				