

Drainage Area = 0.147 sq. mi.

Flood

Design

<u>Overtopping</u>

3ase

Ereg. lΩ

50

100

208

251

.358

Note: Information provided using the USGS Regression Method.

Low Grade Elev. 692.09 @ Sta. 2224+94

Exist.

H.W.E

Head - Ft. Headwater Ei

Prop.

Exist. Prop.

Over | 689.5

Over |690.00

Over Over

Over

690.70

Opening Sq. Ft. Nat.

Prop.

40

40

40

40

Exist.

General Notes

Build tops of headwalls parallel to the grade lines.

\* (205,57,105)RS-2 \*\* CHAMPAIGN & DOUGLAS

COUNTY

SECTION

CONTRACT NO. 70623

All construction joints shall be bonded according to Article 503.09 of the Standard

Reinforcement bars shall conform to the requirements of ASTM A706 Gr. (IL Modified). See Special Provisions.

All bars should be rounded and conform to the requirements of Article 1006.10 of the Standard Specifications.

When lapping sheets of welded wire fabric, the overlap measured between the outermost cross wires of each fabric sheet shall not be less than 8"

End Sections will be paid for at the contract unit price per each for BOX CULVERT END SECTIONS, as outlined in Section 540 of the Standard Specifications.

Class SI Concrete shall be used throughout.

Concrete, Rebar, and Welded Wire Fabric quantities and lengths calculated for the cast-in-place End Sections may vary based on the precast box culverts supplied.

Drain holes shall be provided in accordance with Article 503.11 of the Standard

The precast manufacturer shall design and detail a connection/construction joint between the precast concrete box sections and the cast-in-place apron and wingwall. The minimum area of reinforcement passing through these construction joints shall be 0.20 sq. in./lineal ft. of welded wire fabric. The design shall be detailed in the shop drawings. The cost of the connection is included in the cost of the end section.

The box culvert end section shall be built in the field and a precast option is not allowed except the cut-off wall may be precast. If the contractor elects to use a precast cut-off wall, shop drawings and a proposed construction sequence shall be submitted to the Engineer for approval.

The ends of the precast box sections adjacent to the end section shall be formed without the male and female shapes specified in Article 8.1 of AASHTO M273. See Section D-D on

The design fill height for this box is less than 2 feet. The Precast Concrete Box Culvert Sections shall conform to the requirements of AASHTO M 273.

The joints between precast box sections shall be sealed, all voids filled with a mastic joint sealer. In addition, the joints shall be externally sealed on all four sides with a 13 inch wide external sealing band. The seal shall be centered over the joint, secured in place and protected during the backfilling process.

All dimensions are in FEET (') - INCHES (") unless otherwise noted.

Drawings not to scale.

## TOTAL BILL OF MATERIAL

Item	Unit	Total
Removal of Existing Structures	Each	1
Precast Concrete Box Culverts 10'x2'	Foot	80
Box Culvert End Sections	Each	2
Name Plates	Each	1

SHEET 1 OF 5

GENERAL PLAN AND ELEVATION DOUBLE 10'x2' PRECAST BOX CULVERT F.A.P. ROUTE 808 - SECTION (205,57,105)RS-2 CHAMPAIGN COUNTY STATION 2224+94.00, S.N. 010-2035 CULVERT NO. 11

Opening

DRAIN DETAIL