



NOTES:

1. ALL NECESSARY REVISIONS TO THE WIRING SHOWN ON THIS SHEET SHALL BE MADE AT NO ADDITIONAL COST TO THE DEPARTMENT AND TO THE SATISFACTION OF THE ENGINEER.
2. JUNCTION BOXES FEEDING INDIVIDUAL LUMINAIRES ARE NOT SHOWN.

CONDUIT RUN	CKT	ELECTRIC CABLE	LENGTH (M)
3	F	3-1/C #10	108
	G	3-1/C #10	105
	GND.	1/C #10	108
4	H	3-1/C #10	104
	I	3-1/C #10	107
	J	3-1/C #10	100
	GND.	1/C #10	107

- 400W TUNNEL LUMINAIRE
- 150W TUNNEL LUMINAIRE
- JUNCTION BOX

WIRING DIAGRAMS (NB)
(2 OF 2)

REVISIONS	
NAME	DATE

TUNNEL LIGHTING
CIRCUIT DIAGRAM
NORTHBOUND (2 OF 2)

JOB NO. 94S2063
DATE 8/21/2009

8/21/2009 #FILES
 LAYOUT
 DRAWN
 REVIEWED
 DLH 03/18/04