



## WIRING DETAIL

NO SCALE

### GENERAL NOTES

All taped splices shall use 2 layers of electrical tape over 3 layers of rubber tape as required by the Standard Specifications. Coat the finished taped splice with bonding compound.

All cable splices shall be taped unless another method has been specifically approved by the Engineer.

For example purposes the pole is shown on an anchor base. If the pole is required to be set on a breakaway base, consult the Standard Specifications.

All dimensions are in millimeters (inches) unless otherwise shown.

### POLE HANDHOLE WIRING

REVISIONS	
NAME	DATE
Updated	7/31/08



**HANSON**

JOB NO.  
94S2063  
DATE  
10/6/2009

LGTO08A.DGN

10/6/2009  
#FILE#

LAYOUT	JJH	03/19/04
DRAWN	JJH	
REVIEWED	DLH	