


**DIRECTIONAL BORE NOTE**  
 THE CONTRACTOR WILL EXCAVATE THE EXISTING DUCTS IN ORDER TO INSTALL THE PROPOSED CABLE IN THEM. IF THE DUCTS HAVE COLLAPSED AND THE CONTRACTOR CANNOT INSTALL THE PROPOSED CABLE, THEN AND ONLY THEN WILL THE PROPOSED DIRECTIONAL BORE BE INSTALLED.

THE LOCATION, SIZE AND TYPE OF MATERIAL OF EXISTING UNDERGROUND UTILITIES INDICATED ON THE PLANS IS NOT REPRESENTED AS BEING ACCURATE, SUFFICIENT OR COMPLETE. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE ACTUAL LOCATION OF ALL SUCH FACILITIES, INCLUDING SERVICE CONNECTIONS TO UNDERGROUND UTILITIES. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE UTILITY COMPANIES OF HIS OPERATIONAL PLANS AND SHALL OBTAIN FROM THE RESPECTIVE UTILITY COMPANIES DETAILED INFORMATION AND ASSISTANCE RELATIVE TO THE LOCATION OF THEIR FACILITIES AND THE WORKING SCHEDULE OF THE COMPANIES FOR REMOVAL OR ADJUSTMENT WHERE REQUIRED. IN THE EVENT AN UNEXPECTED UTILITY INTERFERENCE IS ENCOUNTERED DURING CONSTRUCTION, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE UTILITY COMPANY OF JURISDICTION. THE ENGINEER SHALL ALSO BE IMMEDIATELY NOTIFIED. ANY SUCH MAINS AND SERVICES SHALL BE RESTORED TO SERVICE AT ONCE AND PAID FOR BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE CONTRACT.

CALL J.U.L.I.E. FOR UTILITY INFORMATION AT 1-800-892-0123.

- LEGEND**
- EXISTING PAVEMENT
  - EXISTING ELECTRICAL DUCT
  - EXISTING FENCE
  - EXISTING TELEPHONE/COMMUNICATION/DATA CABLE
  - EXISTING ELECTRICAL CABLES
  - EXISTING ELECTRICAL CABLES
  - PROPOSED 1/C #8 5KV & 1/C #8 600V UG CABLE IN U.D.
  - PROPOSED 1/C #8 5KV UG CABLE IN UD
  - EXISTING VAULT
  - PROPOSED STAKE MOUNTED TAXIWAY LIGHT
  - PROPOSED BASE MOUNTED TAXIWAY LIGHT WITH 3/4" DIA. X 50' LONG GROUND ROD
  - EXISTING DUCT MARKER
  - EXISTING ELECTRICAL HANDHOLE




0' 15' 30' 60'  
 HALF SIZE SCALE: 1" = 60'  
 FULL SIZE SCALE: 1" = 30'

DATE	REVISION	BY

TRI-TOWNSHIP AIRPORT  
 SAVANNA, CARROLL COUNTY  
 ILLINOIS

IL. PROJ.: SFY-3932 A.I.P. PROJ.: 3-17-0091-B15

Hanson Project No. 09A0033D_0800	CAH	03/24/09
Filename: R-142ELE.DWG	BAK	03/24/09
Scale: 1" = 30'	CAH	03/24/09
Date: 08/14/09	REVIEWED	
LAYOUT		
DRAWN		



REPLACE MITL SYS.,  
 INSTALL APRON LTS  
 PROPOSED  
 ELECTRICAL PLAN  
 FOR TAXIWAY "A" AND APRON