



THE LOCATION, SIZE AND TYPE OF MATERIAL OF EXISTING UNDERGROUND UTILITIES INDICATED ON THE PLANS IS NOT REPRESENTED AS BEING ACCURATE, SUFFICIENT OR COMPLETE. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE ACTUAL LOCATION OF ALL SUCH FACILITIES, INCLUDING SERVICE CONNECTIONS TO UNDERGROUND UTILITIES. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE UTILITY COMPANIES OF HIS OPERATIONAL PLANS AND SHALL OBTAIN FROM THE RESPECTIVE UTILITY COMPANIES DETAILED INFORMATION AND ASSISTANCE RELATIVE TO THE LOCATION OF THEIR FACILITIES AND THE WORKING SCHEDULE OF THE COMPANIES FOR REMOVAL OR ADJUSTMENT WHERE REQUIRED. IN THE EVENT AN UNEXPECTED UTILITY INTERFERENCE IS ENCOUNTERED DURING CONSTRUCTION, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE UTILITY COMPANY OF JURISDICTION. THE ENGINEER SHALL ALSO BE IMMEDIATELY NOTIFIED. ANY SUCH MAINS AND SERVICES SHALL BE RESTORED TO SERVICE AT ONCE AND PAID FOR BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE CONTRACT.

CALL J.U.L.I.E. FOR UTILITY INFORMATION AT 1-800-892-0123.




LEGEND

- [Solid line] EXISTING PAVEMENT
- [Dashed line] EXISTING ELECTRICAL DUCT
- [Line with 'x'] EXISTING FENCE
- [Line with 'T'] EXISTING TELEPHONE/COMMUNICATION/DATA CABLE
- [Line with 'E'] EXISTING ELECTRICAL CABLES
- [Line with 'E'] EXISTING ELECTRICAL CABLES
- [Line with 'E'] PROPOSED 3-1/C #6 XLP-USE IN DUCT
- [Line with 'E'] PROPOSED 1/C #8 5KV & 1/C #8 600V UG CABLE IN U.D.
- [Line with 'E'] PROPOSED 1/C #8 5KV UG CABLE IN UD
- [Solid black shape] EXISTING VAULT
- [Circle with dot] PROPOSED STAKE MOUNTED TAXIWAY LIGHT
- [Square with dot] PROPOSED BASE MOUNTED TAXIWAY LIGHT
- [Square with 'DM'] EXISTING DUCT MARKER
- [Square with 'HH'] EXISTING ELECTRICAL HANDHOLE

REVISION	DATE	BY

TRI-TOWNSHIP AIRPORT
 SAVANNA, CARROLL COUNTY
 ILLINOIS
 A.I.P. PROJ.: 3-17-0091-B15
 I.L. PROJ.: SFY-3932

Hanson Project No. 09A0033D_0800	LAYOUT	PUG/KNL	08/11/09
Filename: R-143ELE.DWG	DRAWN	MV	08/11/09
Scale: 1" = 20'	REVIEWED	CAH	08/11/09
Date: 08/14/09			



REPLACE MITL SYS.,
 INSTALL APRON LTS
 PROPOSED
 APRON FLOOD LIGHT
 LAYOUT PLAN