


**LEGEND**

2" UD, W/7*6 & 1*6 GND	□	EXISTING COM ED POWER POLE
3" C, W/2" UD	□	SERVICE PEDESTAL
3" C, W/2" UD	—	2" UNIT DUCT 7*6 & 1*6 GROUND (UNLESS NOTED OTHERWISE, SEE NOTE 2)
—	—	3" CONDUIT, PUSHED LENGTH AS SHOWN WITH 2" UNIT DUCT OR AS NOTED
—	—	EXISTING AERIAL UTILITY
●	●	PROPOSED ORNAMENTAL STREET LIGHT, SINGLE TEARDROP FIXTURE, HPS, 250 WATT, 240 VOLT, TYPE IV, 36.5' M.H.
●	●	PROPOSED ORNAMENTAL STREET LIGHT UNIT, COMPLETE, HPS, 150 WATT, 240 VOLT, TYPE IV, 36.5' M.H.
●	●	PROPOSED ORNAMENTAL STREET LIGHT, SINGLE ACORN FIXTURE, HPS, 35 WATT, 120 VOLT, TYPE III, 15.5' M.H.
○	○	EXISTING STREET LIGHT, 400W, MERCURY VAPOR, 30' MH
□	□	PROPOSED LIGHTING CONTROLLER
□	□	PROPOSED HANDHOLE
□	□	EXISTING HANDHOLE
□	□	EXISTING LIGHTING CONTROLLER
SB	SB	SETBACK FROM BACK OF CURB
⌚	⌚	DUPLEX RECEPTACLE, 120V, 20A

- NOTES:**
- 1) THE LIGHTING SYSTEM SHALL BE CONSTRUCTED IN PHASES. LIGHTING SHALL BE MAINTAINED OPERATIONAL ON ONE SIDE OF THE ROAD AS THE OPPOSITE SIDE IS BEING CONSTRUCTED.
  - 2) WEST CIRCUITS USE 2" UD W/5\*6, 3\*4 & \*4GND  
EAST CIRCUITS USE 2" UD W/1\*6 & \*6GND



DRAWN BY: BAKER & WOODMAN, INC. 11/14/12  
 CHECKED BY: GSW 5/14/12  
 DATE: 5-14-12  
 FILE: 100751-SL-3.dwg

	DESIGNED - MWH	REVISED - 8-3-12 PER 100"	<b>VILLAGE OF SKOKIE, ILLINOIS</b> <b>F.A.U. ROUTE 1332 E. OAKTON STREET</b> <b>FROM F.A.P. 350 U.S. ROUTE 41 (SKOKIE BOULEVARD) TO LOWELL AVENUE</b> <b>STREETSCAPE IMPROVEMENTS</b>	<b>STREET LIGHTING PLAN</b> <b>U.S. ROUTE 41 (SKOKIE BOULEVARD)</b>	F.A.U. RTE. 1332	SECTION 11-C0286-00-LS	COUNTY COOK	TOTAL SHEETS 29
	DRAWN - MAC	REVISED			SCALE: 1"=20'	STA. 30+50 TO STA. 42+50	C-91-149-12	CONTRACT NO. 63737
CHECKED - GSW	REVISED	FILE - 100751-SL-3.dwg			FED. ROAD DIST. NO. 1 (ILLINOIS)		FED. AID PROJECT - TE-0016899	
DATE - 5-14-12								