GENERAL NOTES

- BEFORE STARTING ANY EXCAVATION, THE CONTRACTOR SHALL CALL J.U.L.I.E. (1-800-892-0123) FOR FIELD LOCATIONS
 OF BURIED ELECTRIC, TELEPHONE AND GAS FACILITIES. (48 HOURS NOTIFICATION IS REQUIRED).
- 2. THE CONTRACTOR SHALL COORDINATE CONSTRUCTION ACTIVITIES WITH UTILITY COMPANIES, MUNICIPALITIES AND ADJACENT CONTRACTORS.
- THE CONTRACTOR WILL NOT BE ALLOWED TO SET UP A YARD OR FIELD OFFICE ON STATE PROPERTY WITHOUT WRITTEN PERMISSION FROM THE DEPARTMENT.
- 4. BARRICADES: THE CONTRACTOR SHALL PROVIDE AND INSTALL TWO (2) WEIGHTED SAND BAGS ON EACH TYPE I OR TYPE II BARRICADE USED-ONE (1) WEIGHTED SAND BAG ACROSS EACH BOTTOM RAIL.
- 5. WHEN ARTIFICIAL LIGHTING IS UTILIZED IN NIGHT OPERATIONS, THE CONTRACTOR SHALL EXERCISE THE UTMOST PRECAUTIONS IN PREVENTING ADVERSE VISIBILITY TO THE MOTORING PUBLIC AND ADJOINING RESIDENTIAL AREAS.
- 6. SAWCUTTING WILL NOT BE PAID FOR SEPARATELY BUT SHALL BE CONSIDERED INCLUDED IN THE COST OF THE ITEM BEING REMOVED, UNLESS OTHERWISE SPECIFIED.
- 7. POROUS GRANULAR EMBANKMENT, SUBGRADE (PGES) HAS BEEN PROVIDED FOR USE AT THE LOCATIONS INDICATED FOR SOILS THAT TEND TO BE UNSUITABLE OR UNSTABLE. THE ACTUAL NEED FOR REMOVAL AND REPLACEMENT WITH PGES WILL BE DETERMINED IN THE FIELD AT THE TIME OF CONSTRUCTION BY THE GEOTECHNICAL ENGINEER, ALL POTENTIALLY UNSTABLE SOILS SHOULD BE TESTED WITH STATIC CONE PENETROMETER AND TREATED IN ACCORDANCE WITH ARTICLE 301.03 AND THE IDOT STABILITY MANUAL. IF UNSTABLE AND/OR UNSUITABLE MATERIAL IS NOT ENCOUNTERED, THEN THE QUANTITY SHALL BE DEDUCTED AND NO ADDITIONAL COMPENSATION WILL BE DUE TO THE CONTRACTOR.
- 8. ANY REFERENCE TO "STANDARD" THROUGHOUT THE PLANS OR SPECIAL PROVISIONS SHALL BE CONSIDERED TO BE THE "STANDARD SPECIFICATIONS FOR ROAD AND BRIDGE CONSTRUCTION" ADOPTED JANUARY 1, 2002 BY THE STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION, AND "SUPPLEMENTAL SPECIFICATIONS AND RECURRING SPECIAL PROVISONS" DATED MARCH 1, 2005.
- 9. THE STATION/OFFSET/ELEVATIONS NOTED FOR ALL DRAINAGE STRUCTURES LOCATED IN THE CURB LINE REFER TO THE POSITION OF THE ADJACENT PROPOSED EGDE OF PAVEMENT. THE CONTRACTOR SHALL BE RESPONSIBLE FOR DETERMINING THE OFFSET NECESSARY TO THE STRUCTURES TO SET THE FRAME AND GRATES IN THE PROPER LOCATION. ALL OTHER STRUCTURES ARE DIMENSIONED TO THE CENTER OF THE STRUCTURE; ELEVATION INDICATES RIM GRADES.
- 10. THE CONTRACTOR SHALL BE RESPONSBLE FOR CONTACTING LOCAL AGENCIES MAINTAINING SANITARY SEWERS, WATERMAINS, AND STREET LIGHTS TO VERIFY THE MATERIALS AND METHODS ALLOWED FOR ADJUSTMENT, RELOCATION, OR EXTENSION OF THE UTILITY INVOLVED.
- 11. THE LOCATION AND ELEVATION OF EXISTING UTILITIES ARE APPROXIMATE AND ARE PROVIDED BY THE OWNERS, THE EXACT LOCATIONS AND ELEVATIONS ARE TO BE VERIFIED BY THE CONTRACTOR THROUGH THE OWNER OF THE UTILITY.
- 12. THE COST OF MAKING STORM SEWER CONNECTIONS TO EXISTING OR PROPOSED SEWER SHALL BE INCIDENTAL TO THE COST OF NEW STORM SEWER BEING INSTALLED.
- 13. SEWER OR CULVERT TRENCHES CROSSING TRAFFIC LANES SHALL BE TEMPORARILY PATCHED WITH 6 INCHES OF BITUMINOUS BASE COURSE: THE COST OF THE BITUMINOUS BASE COURSE WILL BE INCLUDED IN THE CONTRACT UNIT PRICE FOR THE SEWER OR CULVERT. THIS PRICE SHALL INCLUDE THE COST OF MAINTAINING THE PATCH TO THE SATISFACTION OF THE ENGINEER.
- 14. THE UNIT PRICE FOR ITEMS USED TO CONSTRUCT TEMPORARY PAVEMENT OR ACCESS ROADS SHALL INCLUDE ALL EQUIPMENT, LABOR AND MATERIAL REQUIRED TO PLACE, REMOVE, AND DISPOSE OF THE TEMPORARY PAVEMENT OR ACCESS ROAD.
- 15. THE CONTRACTOR SHALL TRANSPLANT SMALLER TREES (3" TO 5" DIAMETER) TO A NEW LOCATION. THESE TREES ARE MARKED TO BE REMOVED AS SHOWN ON THE ATTACHED EXISTING AND PROPOSED PLANS. THE CONTRACTOR SHALL CONTACT A REPRESENTATIVE FROM THE VILLAGE OF ORLAND PARK 48 HOURS PRIOR TO TRANSPLANTING TREES TO DETERMINE NEW PLANTING LOCATIONS.
- 16. THE "HIGH-EARLY STRENGTH PORTLAND CEMENT CONCRETE PAVEMENT 10" (JOINTED)" QUANTITY SHOWN IN THE SUMMARY OF QUANTITIES IS FOR BIDDING PURPOSES ONLY. THIS ITEM SHALL BE USED AT THE DIRECTION OF THE RESIDENT ENGIVEER, IF THE TRAFFIC MAINTENANCE REQUIRES ITS APPLICATION.
- 17. SUFFICIENT DRAINAGE FACILITIES SHALL BE MAINTAINED THROUGHOUT CONSTRUCTION TO FACILITATE SURFACE RUNOFF.
 WHEN ANY LOOSE MATERIAL IS DEPOSITED IN THE FLOW LINE OF DITCHES, GUTTER OR DRAINAGE STRUCTURES SO THAT THE
 NATURAL FLOW OF WATER IS OBSTRUCTED, IT SHALL BE REMOVED AT THE CLOSE OF EACH WORKING DAY. AT THE CONCLUSION
 OF THE CONSTRUCTION OPERATIONS ALL DRAINAGE STRUCTURES SO AFFECTED SHALL BE FREE FROM DIRT AND DEBRIS.
 THE WORK SHALL BE INCLUDED IN THE COST OF FURNISHED EXCAVATION. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY
 TO PLAN HIS OPERATIONS, WITH THE APPROVAL OF THE ENGINEER IN THE FIELD, SO AS TO UTILIZE THE FACILITIES PROVIDED
 TO PREVENT LOCAL FLOODING AND INSURE PROPER SURFACE RUNOFF. ANY MINOR DITCH GRADING AS DIRECTED BY THE
 ENGINEER, NECESSARY TO PROVIDE FOR THE INTERIM DRAINAGE WILL NOT BE PAID FOR SEPARATELY BUT SHALL BE
 INCLUDED IN THE COST OF THE FURNISHED EXCAVATION.

BITUMINOUS MIXTURE DESIGN TABLE

		DITOMINA	700 11117			
MIXTURE TYPE	UNIT	AC TYPE	MAX RAP %	AIR VOIDS	TYPICAL	MIX TYPE
					THICKNESS	
*TEMPORARY PAVEMENT AND	SEE SUMMARY OF QUANTITIES	PG 64-22	15	4% @ 50 GYR	2"	BITUMINOUS CONCRETE SURFACE COURSE, SUPERPAVE MIX "D", N50
PERMANENT TRANSITION PAVEMENT		PG 58-22	50	2% @ 50 GYR	8''	BITUMINOUS BASE COURSE, SUPERPAVE
	L					Lancia de la companya del companya del la companya del companya de la companya del companya de la companya del la companya de la companya del la companya del la companya de la companya del la com

* SEE SPECIAL PROVISIONS

CONTRACT # 62880

REVISION NAME	DATE		NENT OF TRANSPORTATION AT US RTE 45 (LAGRANGE RD)
		GENERAL NOTE	ES AND COMMITMENTS
		SCALE: N/A	DRAWN BY: JPW
		DATE: 7-07-06	CHECKED BY: RCH
		McDo	nough Associates Inc.