

# GENERAL NOTES

ROUTE NO.	SEC.	COUNTY	TOTAL SHEETS	SHEET NO.
FAI 80 (I-80)	37-1HBR-1	Henry	133	5
FED ROAD DIST. NO.	ILLINOIS	PROJECT		
Contract #64602				

The applicable portions of Article 105.07 of the Standard Specification shall apply except for the following: The Contractor shall be responsible to locate the vertical depths of the underground utilities which may interfere with construction operations. This work will not be measured or paid for separately, but shall be considered as included in the unit bid price for the item of construction involved.

Per SB 699 (90 day utility relocation law), once right-of-way is clear to award the project, a notice will be sent to the utility companies instructing them to have their facilities relocated within 90 days. Estimated date relocation complete = Letting Date + 135 days.

CADD data will be available to Contractors and Consultants working on this project. This information will be provided upon request as MicroStation CADD files and Geopak coordinate geometry files ONLY. If data is required in other formats it will be your responsibility to make these conversions. If any discrepancy or inconsistency arises between the electronic data and the information on the hard copy, the information on the hard copy should be used. Contact the District's Project Engineer to request these files.

It shall be the Contractor's responsibility to contact the municipality to determine approved methods of utility structure adjustment. Utility structures may include, but are not limited to, manholes, water valves, handholes, etc. All materials and work necessary to complete adjustments per municipality requirements shall be considered included in the cost of the associated adjustment pay item.

Where field tile is encountered, Storm Sewer (Special) pipe will be used in accordance with Section 611 of the Standard Specifications. The minimum size for replacement will be 200 mm (8 in.) for Storm Sewer (Special), but the size must be at least 50 mm (2 in.) larger than the adjoining tile. A field tile junction vault will be constructed at the right-of-way line in order to connect the tile and storm sewer (special) pipe.

These items have been included in this contract as contingency items for locating and replacing existing farm tile systems crossing within the proposed right-of-way:

EXPLORATION TRENCH (48")	750.00 LIN. FT.
FIELD TILE JUNCTION VAULT (2' DIA.)	4 EACH
STORM SEWER SPECIAL 8"	100 LIN. FT.
STORM SEWER SPECIAL 10"	100 LIN. FT.
STORM SEWER SPECIAL 12"	100 LIN. FT.

Commitments:

1. The Contractor will not reconstruct both the Private Entrance located at Sta. 39+75 LT and the Field Entrance located at Sta. 41+65 LT simultaneously. Only one of the above entrances shall be constructed at any given time.
2. Throughout the construction process the Contractor will not disturb the following:
  - a. Existing well located at Sta. 38+87 approximately 45-feet LT of centerline.
  - b. Two trees located adjacent to the Private Entrance (Sta. 38+67 LT) located at Sta. 38+58 LT and Sta. 38+78 LT, both of which are approximately 33 feet LT of centerline.
  - c. Trees located at Sta. 38+37 RT approximately 33 feet RT of centerline, Sta. 37+54 RT approximately 34 feet RT of centerline, Sta. 37+89 RT approximately 34 feet RT of centerline, and Sta. 38+78 approximately 33 feet RT of centerline.
  - d. Existing sign located at Sta. 38+42 RT approximately 35.50 feet RT of centerline.
  - e. The tree located on Carroll Street, Sta. 101+04 RT approximately 50 feet RT of centerline.
  - f. The "Well Hand Pump" located at Sta. 48+21.40 approximately 76 feet LT of centerline.
3. The Contractor will not plant trees within the State right-of-way from Sta. 53+00 RT to Sta. 63+70 RT.
4. The Contractor shall install woven wire fence and woven wire fence gate as shown on the project plans from Sta. 38+64 RT to Sta. 50+45 RT.

Program #5  
(Arch. Size)  
Enlarge  
200%  
Enlarge 107%