QUANTITIES

QUANTITY CALCULATIONS ARE ON

BUREAU OF PROJECT IMPLEMENTATION;

FILE AT THE DISTRICT 4 OFFICE;

DOCUMENTATION SECTION


DATE:

DATE:

CALC. BY:

CHECKED BY:

SLOPE DRAIN FOR BURIED PIPES



GENERAL NOTES

- 1. The material for Pipe Drains shall be bituminous coated galvanized corrugated steel culvert pipe or bituminous coated corrugated aluminum alloy pipe in accordance with Article 601.02(b) or 601.02(e) or Polyvinyl Chloride (PVC) pipe in accordance with Article 601.02 (s).
- 2. An approved mastic material (Article 1055.01) shall be applied to the inside of the connecting bands.

All dimensions are in inches unless otherwise noted.

COUNTY	FETS NO
OFFE	ETO NO.
O1 CONTRACT NO.).
FED. AID PROJECT	
0110 SIC	i01101 CONTRACT NC