



**LIGHTING CABINET LC-1 - ELEVATIONS**  
 NOT TO SCALE

- NOTES**
- EXTERIOR 12GA. 304 STAINLESS STEEL AND INTERIOR 14 GA. COLD ROLLED STEEL ELECTRONICALLY WELDED AND REINFORCED WHERE REQUIRED.
  - CONSTRUCTION SHALL BE NEMA 3R, RAIN TIGHT.
  - ALL NUTS, BOLTS, SCREWS AND HINGES SHALL BE STAINLESS STEEL AND NOT VISIBLE FROM OUTSIDE ENCLOSURE.
  - PHENOLIC NAMEPLATES SHALL BE PROVIDED AS REQUIRED.
  - CONTROL WIRING SHALL BE MARKED AT BOTH ENDS BY PERMANENT WIRE MARKERS.
  - A PLASTIC COVERED WIRING DIAGRAM SHALL BE ATTACHED TO THE INSIDE OF THE FRONT DOOR.
  - UL LISTED INDUSTRIAL CONTROL PANEL, FROM EXCEL LIMITED, TESCO CONTROLS, MILBANK MANUFACTURING OR ENGINEER APPROVED EQUAL.

- NOTES**
- SEE ELECTRICAL SERVICE LIGHTING CONTROL CABINET 'LC-1' DETAIL, THIS DRAWING.
  - PANEL TO BE INSTALLED IN OVERALL ENCLOSURE AS SHOWN.
  - PROPOSED LOADING 10KVA LIGHTING, 32 KVA RECEPTACLE, 200A PANEL

**INSTALLATION ONE LINE DIAGRAM-LC-1**

1  
 NOT TO SCALE



David M. Tepel  
 SIGNATURE  
 11/30/2009  
 EXPIRATION DATE  
 10-02-09  
 DATE

Date	09-30-09	Sheet	34 of 50
Scale	NOT TO SCALE		
MFT PROJ. #	09-00242-00RP	DESIGNER	DFW
Date		Revision	