

- 1. SEE DRAWING E-01 FOR IDOT ELECTRICAL SYMBOLS AND ABBREVIATIONS.
- 2. LOCATIONS OF EXISTING ELECTRICAL EQUIPMENT SHOWN ON THIS DRAWING ARE APPROXIMATIONS AND MUST BE VERIFIED IN THE FIELD BY THE CONTRACTOR.
- 3. THE REMOVAL OF EXISTING UNDERPASS LUMINAIRES MUST INCLUDE THE REMOVAL OF ALL CABLES, CONDUIT, JUNCTION BOXES, AND HARDWARE ASSOCIATED WITH THE EXISTING UNDERPASS LIGHTING, COST FOR THIS WORK WILL NOT BE PAID FOR SEPARATELY BUT WILL BE INCLUDED AS PART OF THE "REMOVAL OF LIGHTING UNIT, SALVAGE" PAY ITEM.
- 4. SEE IDOT STANDARD DRAWING BE-902 FOR ADDITIONAL INSTALLATION DETAILS FOR PROPOSED PIER/ABUTMENT WALL 9. SEE DRAWING E-04 FOR CONTINUATION OF LIGHTING MOUNTED UNDERPASS LUMINAIRES.
- 5. SEE IDOT STANDARD DRAWING BE-900 FOR ADDITIONAL INSTALLATION DETAILS FOR PROPOSED SUSPENDED MOUNT UNDERPASS LUMINAIRES.
- 6. ALL PROPOSED UNDERPASS LIGHTING UNITS SHOWN ON THIS DRAWING WILL BE FED FROM EXISTING IDOT LIGHTING CONTROLLER "G".
- 7. SUSPENDED MOUNT UNDERPASS LUMINAIRES SETBACK FROM THE EDGE OF PAVEMENT SHALL BE 2 FEET.
- ALL VERTICAL CONDUIT RUNS ROUTED DOWN THE STRUCTURE SHALL BE INSTALLED ON THE INSIDE OF THE PIER FACING AWAY FROM TRAFFIC FLOW.

## PROPOSED UNDERPASS LIGHTING PLAN

- 10. ROUTE NEW CABLES IN UNIT DUCT FROM PROPOSED JUNCTION BOX ON HALSTED ST. BRIDGE TO THE PROVIDE A TEMPORARY POWER CONNECTION FOR THE UNDERPASS LIGHTING SYSTEM FROM EXISTING LIGHT TOWER ZCO2. ALLOW 200 FEET OF CABLES IN UNIT DUCT FOR BIDDING PURPOSES.
- 11. ROUTE NEW CABLES IN UNIT DUCT FROM PROPOSED JUNCTION BOX ON PEORIA ST. BRIDGE TO THE EXISTING LIGHTING CIRCUITS LOCATED IN THE EXISTING LIGHT POLE TO PROVIDE A TEMPORARY POWER CONNECTION AS SHOWN. SEE DRAWING E-03 FOR CONTINUATION.
- 12. SEE DRAWING E-03 FOR TEMPORARY POWER CONNECTIONS TO UNDER PASS LIGHTING SYSTEM.

## 100 WATT, HPS UNDERPASS LUMINAIRE WITH TYPE 4 DISTRIBUTION

	JUNCTION BOX SCHEDULE				
NO.	SIZE	DESCRIPTION			
JB1	6′′X6′′X4′′	STAINLESS STEEL, ATTACHED TO STRUCTURE, UNDERPASS LIGHTING			
JB2 12''X10''X6''		STAINLESS STEEL, ATTACHED TO STRUCTURE, UNDERPASS LIGHTING			
JB3	18''X18''X8''	STAINLESS STEEL, ATTACHED TO STRUCTURE, UNDERPASS LIGHTING			

	CABLE	/	CONDUIT	SCHEDULE	

- 3-1/C\*10, 1-1/C\*10 GND IN 1" DIA PVCC RGC ATTACHED TO STRUCTURE (CKTS AS INDICATED ON THIS DRAWING)
- 2-1/C\*10, 1-1/C\*10 GND IN 1" DIA PVCC RGC ATTACHED TO STRUCTURE (CKTS AS INDICATED ON THIS DRAWING)
- 2-1/C\*10, 1-1/C\*10 GND IN 1" DIA LIQUID TIGHT FLEXIBLE CONDUIT (CKTS AS INDICATED ON THIS DRAWING)
- 3-1/C\*2, 1-1/C\*4 GND XLP TYPE USE CABLES IN A 1 1/2" UNIT DUCT (CKTS AS INDICATED ON THIS DRAWING)
- 3-1/C"2, 1-1/C"4 GND XLP TYPE USE CABLES IN A 3" DIA, PVCC RGC ATTACHED TO STRUCTURE (CKTS AS INDICATED ON THIS DRAWING)

E-05

**AECOM** 

D160W29-sht-Light-05	DESIGNED - WDS	REVISED -
USER NAME = BAWitort	DRAWN - CAM	REVISED -
PLOT SCALE = 40.0000 '/ in.	CHECKED - WDS	REVISED -
PLOT DATE = 10/28/2013	DATE - 10/30/2013	REVISED -

**STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION** 

	PEORIA	STREE	T UI	NDERPAS	S LIGH	TING PLAN	F.A.I RTE. 90/94/
SCALE: 1"=20"	SHEET	5 C	F 19	9 SHEETS	STA.	TO STA.	

A.I. E.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.		
4/290	2013-011R	COOK	356	115		
CONTRACT NO. 60W29						
THE THORSE SERVICE AND DROUGHT						