



# Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

January 10, 2020

SUBJECT: Route TR 11 (McNeal Road)  
Section 13-05119-01-BR  
DeKalb County  
Contract No. 87688  
Item 117  
January 17, 2020 Letting  
Addendum A

## NOTICE TO PROSPECTIVE BIDDERS:

Attached is an addendum to the plans or proposal. This addendum involves revised and/or added material.

- 1. Revised page 8 of the special provisions**
- 2. Revised plan sheets 2, 3, 5, 8, 12 & 17**
- 3. Revised Schedule of Prices**

Prime contractors must utilize the enclosed material when preparing their bid and must include any changes to the Schedule of Prices in their bid.

Very truly yours,

A handwritten signature in black ink, appearing to read 'Jack A. Elston'.

Jack A. Elston, P.E.  
Bureau Chief, Design and Environment

**1 EQUIPMENT ON LOAD-LIMITED STRUCTURES**

Structure No. **019-4009** is restricted to a 5-Ton load limit. Construction equipment that exceeds this load limit shall not be allowed to cross the existing structure in its current condition, according to Article 107.16 of the Standard Specifications. The contractor will not be allowed to work from the bridge to build cofferdams, unless the structure is first modified to accommodate heavier equipment. Any such modifications shall be submitted for approval as a part of the Contractor's demolition plan, including detailed working drawings showing the proposed modifications, and supporting calculations to justify the increased load, sealed by an Illinois-licensed Structural Engineer. This documentation shall include a list of all construction vehicles in excess of 5 tons which are proposed, and no vehicles not listed will be allowed on the structure. Any damage to the existing structure, due to equipment not meeting these requirements, shall be repaired or replaced at the Contractor's expense.

**EXPLORATION TRENCH, SPECIAL**

(Revised January 1, 2007)

This work shall consist of constructing a trench for the purpose of verifying clearances and locations of existing utilities and storm sewers. The exploration trench shall be constructed at the locations directed by the Engineer.

The depth of the trench shall be variable. The width of the trench shall be sufficient to allow proper investigation of the entire trench.

After the trench has been inspected by the Engineer. The excavated material shall be used to backfill the trench in a manner satisfactory to the Engineer. Any excess materials shall be disposed of according to Article 202.03 of the Standard Specifications.

This work will be paid for at the contract unit price per foot (meter) for EXPLORATION TRENCH, SPECIAL.

**MULCH METHOD 2**

(Effective August 1, 1994; Revised January 1, 2007)

Article 251.03 Method 2 Procedure 1 of the Standard Specifications shall be required for this improvement.

---

<sup>1</sup> ADDENDUM NO. 1 REV DATE 01/08/2020 SP PAGE 8