



NOTES:

1. ALL FIXTURES SHOWN ON BESSIE COLEMAN DRIVE TO BE 480V, 1PH. MATCH VOLTAGE WITH EXISTING LIGHTING CIRCUIT.
2. ALL CONDUITS (UNDERGROUND) TO BE PVC CONCRETE ENCASED, SIZE AS SHOWN ON PLAN.
3. THE PROPOSED LIGHTING FIXTURE VOLTAGE SHALL MATCH WITH THE EXISTING LIGHTING FIXTURE VOLTAGE OF CITY OF ROSEMONT.



USER NAME = mali	DESIGNED - HS	REVISED -
PLOT SCALE = *SCALE*	DRAWN - KK	REVISED -
PLOT DATE = 10/5/2012	CHECKED - HS	REVISED -
	DATE - 10-19-2012	REVISED -

**STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION**

**PROPOSED LIGHTING PLAN
ZEMKE BLVD AND BESSIE COLEMAN DRIVE**

SCALE: 1" = 50' SHEET NO. OF SHEETS STA. 7+46.78 TO STA. 64+18.43

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
330	0105-WRS	COOK	537	293
CONTRACT NO. 60P35				
ILLINOIS FED. AID PROJECT				

FILE NAME = c:\cadd\lib\pw\khan\pgr\great.lakes\dms47849\0160P35-shr-light-6.dgn