



- NOTES:**
1. REFER TO DRAWING E1 FOR GENERAL NOTES, LEGEND AND ABBREVIATIONS.
  2. REFER TO DRAWINGS E15 THRU E20 FOR DETAILS.
  3. REFER TO DRAWING E21 FOR LIGHT POLE SCHEDULE AND DRAWING E22 FOR LIGHTING SINGLE LINE DIAGRAM.
  4. CONTRACTOR SHALL PROVIDE TEMPORARY LIGHTING PRIOR TO DEMOLITION WORK. PROVIDE TEMPORARY POLE AND OVERHEAD TEMPORARY CIRCUIT. CONNECT TO EXISTING LIGHTING CIRCUIT IN AREA. COORDINATE EXACT TEMPORARY POLE QUANTITY AND LOCATION WITH VILLAGE OF ARLINGTON HEIGHTS.
  5. LOCATION OF EXISTING CONDUIT AND CABLE IS APPROXIMATE. FIELD VERIFY REQUIRED FOR EXACT LOCATION OF CONDUIT ROUTING.
  6. POLE SETBACK IS MEASURED FROM ROADWAY CENTERLINE TO CENTER OF POLE.



REVISIONS	
NAME	DATE

E3 OF E24

VILLAGE OF ARLINGTON HEIGHTS

**TEMP. LIGHTING PLAN-1**

U.S. ROUTE 14  
STA. 547+04 TO STA. 551+00

0 HORIZ.  
20 SCALE IN FEET 20 VERT.

DATE: 08/17/2012  
DESIGNED BY: EE  
TECHNICIAN: EE  
CHECKED BY: DEM