



Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

March 1, 2012

SUBJECT: Various Routes
Project TE-00D6(107)
Section 10-00035-00-LS (Litchfield)
Montgomery County
Contract No. 93563
Item 111
March 9, 2012 Letting
Addendum (B)

NOTICE TO PROSPECTIVE BIDDERS:

Due to clarify information necessary to revise the following:

1. Page 3 of the Special Provisions.

Prime contractors must utilize the enclosed material when preparing their bid and must include any Schedule of Prices changes in their bidding proposal.

Bidders using computer-generated bids are cautioned to reflect any and all Schedule of Prices changes, if involved, into their computer programs.

Very truly yours,

John Baranzelli, P.E.
Acting Engineer of Design and Environment

A handwritten signature in cursive script, reading "Ted B. Walschleger, P.E.", with the initials "P.E." written in a smaller font to the right.

By: Ted B. Walschleger, P.E.
Engineer of Project Management

PORTLAND CEMENT CONCRETE SIDEWALK, 4 INCH, SPECIAL

This item shall consist of constructing a Portland cement concrete sidewalk on a prepared subgrade in accordance with Section 424 of the Standard Specifications except as modified herein:

Textured sidewalk shall be constructed at the locations shown on the plans. Textured sidewalk shall be colored and textured to replicate the appearance of brick pavers in a basket weave pattern. The Contractor shall submit shop drawings, consisting of color and texture samples and manufacturer's specifications of the textured sidewalk products and construction procedures to the Engineer for approval. The color of the new sidewalk shall be integral and shall match the color of the existing imprinted sidewalk on State Street, between Union Street and Edwards Street.

~~Textured sidewalk shall consist of a Portland cement concrete, colored with a surface-applied color hardener, stenciled for texture. The hardener shall be Scofield "Lithochrome® Color Hardener", Matcrete "Dustone® Color Hardener", Brickform "Color Hardener", or approved equal. The application of the hardener, sealer, and texture shall be in accordance with the manufacturer's recommendations.~~

Curb ramps accessible to the disabled shall **not** be imprinted. Curb ramps, including associated curbs or flares, shall be constructed with ordinary Portland cement concrete in accordance with the applicable Highway Standards.

This item of work will be paid for at the contract unit price per square foot for Portland Cement Concrete Sidewalk, 4 Inch, Special, which price shall include all work necessary to construct the concrete walk and successfully color and texture the sidewalk.

SIDEWALK GRADES

Sidewalk grades shall be in accordance with the Plans and the Public Rights-of-Way Accessibility Guideline (PROWAG).

Proposed sidewalk elevations shall match the existing elevation at the building line as shown on the typical sections. The maximum cross-slope on any sidewalk shall not exceed 2%, except in stamped areas which are not considered part of the accessible route. Sidewalk ramps to be constructed are shown on the plans and shall not exceed a grade of 8.3%. Proposed sidewalk not indicated as ramped shall not exceed a 5% grade. If areas where existing sidewalks exceed a 5% grade, or where a proposed sidewalk will exceed a 5% grade due to grade changes, a sidewalk ramp not exceeding a grade of 8.3% shall be installed, for a maximum distance of 30 feet. At each end of such a ramp, a landing with a slope not exceeding 2% shall be provided for a minimum of 5 feet.

Compliance with this special provision will not be paid for separately, but will be considered included in the unit price for Portland Cement Concrete Sidewalk, 4 Inch.