

# GENERAL NOTES

The Contractor shall be responsible for protecting utility property during construction operations as outlined in Article 107.31 of the Standard Specifications. A minimum of 48 hours advance notice is required for non-emergency work. The JULIE number is 800-892-0123. The following listed utilities located within the project limits or immediately adjacent to the project construction limits are members of JULIE:

Commonwealth Edison Co. (815/490-2869)	Verizon (815/895-1515)
NICOR Gas Co. (630/983-8676)	Comcast (630/600-6352)
Mediacom (630/365-0045)	City of Belvidere (815/544-9256)

The applicable portions of Article 105.07 of the Standard Specification shall apply except for the following: The Contractor shall be responsible to locate the vertical depths of the underground utilities which may interfere with construction operations. This work will not be measured or paid for separately, but shall be considered as included in the unit bid price for the item of construction involved.

Per SB 699 (90 day utility relocation law), once right-of-way is clear to award the project, a notice will be sent to the utility companies instructing them to have their facilities relocated within 90 days. Estimated date relocation complete = Award Date + 100 days.

CADD data will be available to Contractors and Consultants working on this project. This information will be provided upon request as MicroStation CADD files and Geopak coordinate geometry files ONLY. If data is required in other formats it will be your responsibility to make these conversions. If any discrepancy or inconsistency arises between the electronic data and the information on the hard copy, the information on the hard copy should be used. Contact the District's Project Engineer to request these files.

The cost of the connection of the Insertion Culvert Liner 36" with the Precast Reinforced Concrete Flared End Sections 36" shall be included in the contract unit price for INSERTION CULVERT LINER 36".

Due to the drop box height restriction, only a RPM-D3262 type insertion culvert liner, as specified in Article 543.02 of the Standard Specifications, may be used.

To help avoid excess drop offs at the edge of pavement, aggregate shall be placed and rolled to match the edge of pavement before any widening work is started. All costs associated with placing and rolling the aggregate shall be considered included in the contract unit price per Ton for AGGREGATE SHOULDERS, TYPE B.

The subgrade areas scheduled to be improved to a depth greater than 300 mm (12") are estimated based on the original geotechnical investigation. The subgrade shall be processed in accordance with Article 301.03 of the Standard Specifications before the engineer shall determine the limits and the additional thickness of improvement required, if any. Any additional undercutting required after this evaluation shall be paid for as EARTH EXCAVATION.

FILE NAME = 64F80.GN.DOCX	USER NAME =	DESIGNED - Engineering Systems	REVISED -	<b>STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION</b>	<b>GENERAL NOTES</b>	ROUTE	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.	
		DRAWN -	REVISED -			FAP 517	L-M-4	Boone	54	9	
	PLOT SCALE =	CHECKED -	REVISED -			(US Bus 20)		CONTRACT NO. 64F80			
	PLOT DATE = 12/9/2010 2:32 PM	DATE - 6/2/2010 9:31 AM	REVISED -			SCALE:	SHEET NO.	OF	SHEETS	STA.	TO STA.