TRANSPORTATION BULLETIN



ADDENDUM NO. 1

Dated: March 4, 2011

For: Transportation Bulletin Letting Date: March 11, 2011 Volume 14, No. 5 Dated: February 4, 2011

<u>Item No. 2A – Mike Apron Expansion</u>

MidAmerica St. Louis Airport Mascoutah, Illinois St. Clair County

IL Project No.: BLV-4061 AIP Project No.: 3-17-0146-xx

Contract No.: SC066

REASON FOR ADDENDUM:

Construction Plan Revisions Section III - Special Provisions Revision

TO ALL PLAN HOLDERS:

CONSTRUCTION PLANS

Revised plan sheet 4 of 53.

The geographic coordinates of critical points were incorrect. The coordinates used for the control are in the Scott Joint Use 1993 Datum and need a conversion factor of 0.999934463 to be converted to state plane.

Revised plan sheet 32 of 53.

The exhaust fan needs to have a control switch located inside the mobile fumigation office. Note, this work is incidental to the lump sum reinstall fumigation facility pay item.

SECTION III - SPECIAL PROVISIONS

Page 24: Delete section 501-2.4 and replace with the original language from the Standard Specifications for Construction of Airports (Consolidated Reprint), dated November 2, 2009.

Premolded joint filler meeting the requirements of ASTM D 1751 will be allowed.