



ELBOWS SHALL BEAR THE LABEL OF THE UNDERWRITERS LABORATORIES INC., AND MEET SPECIFICATIONS OF UNDERWRITERS LABORATORIES, INC. NO. 6, UNITED STATES OF AMERICA. STANDARDS INSTITUTE, C80.1 AND FEDERAL SPECIFICATIONS WW-C-581E AND WF-408C WHERE APPLICABLE.

NOTE:
TWO THREAD PROTECTORS TO BE FURNISHED ON EACH ELBOW, PROTECTOR TO COVER A MINIMUM OF TEN THREADS.

TABLE OF DIMENSIONS				
CONDUIT SIZE	DIMENSIONS			COMMODITY CODE
	"A"	"C"	"D"	
1 1/4"	24"	35"	11"	09-4001-0510
1 1/2"	24"	35"	11"	09-4001-0520
2"	24"	35"	11"	09-4001-4126
2 1/2"	24"	35"	11"	09-4001-4128
3"	24"	35"	11"	09-4001-4230
4"	24"	35"	11"	09-4001-0000

B SPECIFICATIONS REVISED
A REVISED DIMENSIONS ON 3" x 4" CONDUIT L.P.
ELBOW, CONDUIT, RIGID GALVANIZED STEEL, LARGE RADIUS

REVISED	CITY OF CHICAGO	
A 7-22-71	DEPT. OF STREETS AND SANITATION	
B 4-3-79	BUREAU OF ELECTRICITY	
C	DIVISION OF ELECTRICAL ENGINEERING	
D	DRAWN	CHECKED
E	LON BURDY	M.S.
F	ENGINEER	M. SHINE
G	DRG. NO.	11825
	DEPUTY CHIEF	DATE 6-2-71
	SIZE 8 1/2" x 14"	SCALE 3/16"

REVISIONS	
NAME	DATE

ILLINOIS DEPARTMENT OF TRANSPORTATION
 CITY OF CHICAGO
 BUREAU OF ELECTRICITY
 LIGHTING STANDARDS
 SAYRE AVENUE OVER
 INTERSTATE 90 (KENNEDY EXPRESSWAY)
 SCALE: NONE
 DATE: 2/1/2008
 DRAWN BY: MAE
 CHECKED BY: MK/PKG

154139 14 JAN 2009 I:\PROJECTS\Projects_200\PatrickEndsavage\DETAILS\2007\E9_27 of 71-Citydetail18.dgn