



- NOTES:**
1. EXTEND EXISTING UNIT DUCT AND ROUTE INTO NEW FOUNDATION OR NEW HANDHOLE. REUSE EXISTING WIRING IF LENGTH IS SUFFICIENT. IF NOT, REMOVE EXISTING WIRING BACK TO NEXT FOUNDATION/HANDHOLE AND INSTALL NEW 1/2" #6, 1/2" #6 NEUTRAL, & 1/2" #6 GROUND. REMOVING EXISTING CABLE IN CONDUIT WILL NOT BE PAID FOR SEPARATELY, CONTRACTOR MAY SALVAGE REMOVED WIRE. SPLICING NEW WIRING IN EXISTING LIGHT POLES/HANDHOLES WILL BE PAID FOR "CABLE SPLICING, SPECIAL".
 2. CONTRACTOR SHALL TAKE FULL MAINTENANCE OF EXISTING LIGHTING CONTROLLER "E" AND PARTIAL MAINTENANCE OF EXISTING CONTROLLERS "G" & "O". SEE SPECIAL PROVISIONS.
 3. REMOVING EXISTING HANDHOLE AND REPLACING WITH NEW HANDHOLE SHALL BE PAID FOR UNDER "RELOCATE EXISTING HANDHOLE".

FILE NAME =	USER NAME = PRAZALAN	DESIGNED -	REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	ROADWAY LIGHTING IMPROVEMENTS - JACKSON BLVD. LIGHTING PLAN	F.A. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.	
McFORESTPARK\070001\Mech\LG\070001.DWG	SHT	DRAWN -	REVISED -			1462	07-00105-00-PV	COOK	49	27	
	PLOT SCALE = 20'	CHECKED -	REVISED -			CONTRACT NO. 63134					
	PLOT DATE = 2/17/2009	DATE -	REVISED -			FED. ROAD DIST. NO. 1 (ILLINOIS) FED. AID PROJECT					
						SCALE:	SHEET NO.	OF	SHEETS	STA.	TO