



WIRING DETAIL

NO SCALE

GENERAL NOTES

- All taped splices shall use 2 layers of electrical tape over 3 layers of rubber tape as required by the Standard Specifications. Coat the finished taped splice with bonding compound.
- All cable splices shall be taped unless another method has been specifically approved by the Engineer.
- For example purposes the pole is shown on an anchor base. If the pole is required to be set on a breakaway base, consult the Standard Specifications.

All dimensions are in millimeters (inches) unless otherwise shown.

FILE NAME =	USER NAME = laughlinr1	DESIGNED -	REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	POLE HANDHOLE WIRING				F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
et:\pw\work\PWIDOT\LAUGHLINRL\dms76543\672C46-shd-detail.s.dgn		DRAWN -	REVISED -		668	28L-1	SANGAMON	20	18				
PLOT SCALE = 40.0000 ' / IN.		CHECKED -	REVISED -		CONTRACT NO. 72C46				ILLINOIS FED. AID PROJECT				
PLOT DATE = Feb-05-2009 02:56:34PM		DATE -	REVISED -		SCALE:	SHEET NO.	OF SHEETS	STA.	TO STA.				