



FEB 10, 2009 4:51 PM HAGL000362  
 I:\AIRPORTS\STLOUIS\B37-06RWYD\AIRPORT\SHEETS\R-142ELE.DWG - RWY 17-35



SR085




DETAIL "A"




DETAIL "B"



DETAIL "C"



DETAIL "D"




DETAIL "E"

THE LOCATION, SIZE AND TYPE OF MATERIAL OF EXISTING UNDERGROUND UTILITIES INDICATED ON THE PLANS IS NOT REPRESENTED AS BEING ACCURATE, SUFFICIENT OR COMPLETE. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE ACTUAL LOCATION OF ALL SUCH FACILITIES, INCLUDING SERVICE CONNECTIONS TO UNDERGROUND UTILITIES. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE UTILITY COMPANIES OF HIS OPERATIONAL PLANS AND SHALL OBTAIN FROM THE RESPECTIVE UTILITY COMPANIES DETAILED INFORMATION AND ASSISTANCE RELATIVE TO THE LOCATION OF THEIR FACILITIES AND THE WORKING SCHEDULE OF THE COMPANIES FOR REMOVAL OR ADJUSTMENT WHERE REQUIRED. IN THE EVENT AN UNEXPECTED UTILITY INTERFERENCE IS ENCOUNTERED DURING CONSTRUCTION, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE UTILITY COMPANY OF JURISDICTION. THE ENGINEER SHALL ALSO BE IMMEDIATELY NOTIFIED. ANY SUCH MAINS AND SERVICES SHALL BE RESTORED TO SERVICE AT ONCE AND PAID FOR BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE CONTRACT.

CALL J.U.L.I.E. FOR UTILITY INFORMATION AT 1-800-892-0123.

LEGEND

- EXISTING IMPROVEMENTS
- EXISTING 1/C #8 5KV U.G. CABLE IN U.D.
- EXISTING UNDERGROUND ELECTRIC
- EXISTING 1/C #8 5KV U.G. CABLE IN U.D. TO BE LEFT IN PLACE
- PROPOSED 1/C #8 5KV U.G. CABLE IN U.D.
- EXISTING ELECTRICAL DUCT
- EXISTING STAKE MOUNTED RUNWAY LIGHT
- EXISTING STAKE MOUNTED TAXIWAY LIGHT
- EXISTING BASE MOUNTED TAXIWAY LIGHT
- EXISTING TAXI GUIDANCE SIGN
- EXISTING ELECTRICAL DUCT MARKER
- EXISTING DISTANCE REMAINING SIGN (TO BE RELOCATED)
- EXISTING FAA VASI
- PROPOSED DISTANCE REMAINING SIGN
- PROPOSED WIND CONE



| QUANTITIES THIS SHEET |                                   |      |          |
|-----------------------|-----------------------------------|------|----------|
| ITEM NO.              | DESCRIPTION                       | UNIT | QUANTITY |
| AR108158              | 1/C #8 5KV UG CABLE IN UD         | L.F. | 891      |
| AR125965              | RELOCATE RWY DISTANCE REMAIN SIGN | EACH | 5        |

|  |   |  |  |
|--|---|--|--|
| <b>ST. LOUIS REGIONAL AIRPORT</b><br><br><b>EAST ALTON, ILLINOIS</b>                         | A.I.P. PROJ.: 3-17-0002-842<br>I.L. PROJ.: AIN-3825 | HANSON<br><br>Hanson Professional Services Inc.<br>1325 South Sixth Street<br>Springfield, IL 62705-2886<br>Offices Nationwide | <b>RUNWAY SAFETY AREA IMPROVEMENTS</b><br>PROPOSED ELECTRICAL PLAN FOR RUNWAY END 17-35<br><div style="font-size: 2em; font-weight: bold; margin-top: 10px;">46</div> <small>46 of 81 sheets</small> |
| HB Project No. 83708RWYD.0800<br>Filename: R-142ELE.DWG<br>Scale: 1" = 50'<br>Date: 02/11/08 | REVISION<br>DATE                                    | LAYOUT CAH 02/11/08<br>DRAWN MDR 02/11/08<br>REVIEWED CAH 07/11/08   | BY<br>REVISION<br>DATE   |