



# Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

April 16, 2015

SUBJECT: FAU Route 3887 (IL 31/Main St.)  
Section 2014-082I  
Kane County  
Contract No. 62A30  
Item No. 32, April 24, 2015 Letting  
Addendum A

## NOTICE TO PROSPECTIVE BIDDERS:

Attached is an addendum to the plans or proposal. This addendum involves revised and/or added material.

1. Revised the Table of Contents to the Special Provisions
2. Revised pages 24 & 33 of the Special Provisions

Prime contractors must utilize the enclosed material when preparing their bid and must include any Schedule of Prices changes in their bidding proposal.

Bidders using computer-generated bids are cautioned to reflect any and all Schedule of Prices changes, if involved, into their computer programs.

Very truly yours,

John D. Baranzelli, P.E.  
Acting Engineer of Design and Environment

A handwritten signature in cursive script, reading "Ted B. Walschleger" followed by a small "P.E." to the right.

By: Ted B. Walschleger, P. E.  
Engineer of Project Management

cc: John Fortmann, Region 1, District 1; Laura Mlacnik; Tim Kell;  
D. Carl Puzey; Estimates

MS/kf

## TABLE OF CONTENTS

LOCATION OF PROJECT .....	1
DESCRIPTION OF PROJECT.....	1
STATUS OF UTILITIES TO BE ADJUSTED .....	1
TRAFFIC CONTROL PLAN.....	2
WORK RESTRICTIONS.....	3
REMOVAL OF EXISTING STRUCTURES .....	3
GRANULAR CULVERT BACKFILL .....	3
MAINTENANCE OF ROADWAYS.....	4
RECLAIMED ASPHALT PAVEMENT FOR NON-POROUS EMBANKMENT AND BACKFILL....	4
TRAFFIC CONTROL AND PROTECTION (ARTERIALS).....	4
COARSE AGGREGATE FOR BACKFILL, TRENCH BACKFILL AND BEDDING (D-1) .....	5
EMBANKMENT II.....	5
GROUND TIRE RUBBER (GTR) MODIFIED ASPHALT BINDER (D-1) .....	7
HMA MIXTURE DESIGN REQUIREMENTS (D-1).....	8
PUBLIC CONVENIENCE AND SAFETY .....	25
RECLAIMED ASPHALT PAVEMENT AND RECLAIMED ASPHALT SHINGLES (D-1).....	25
PRUNING FOR SAFETY AND EQUIPMENT CLEARANCE .....	36
PROTECTION OF EXISTING TREES.....	37
SEEDING, CLASS 3 (MODIFIED) .....	40
TRAFFIC SIGNAL SPECIFICATIONS.....	42
AUTOMATED FLAGGER ASSISTANCE DEVICES (BDE).....	101
CONSTRUCTION AIR QUALITY – DIESEL RETROFIT (BDE) .....	102
CONTRACT CLAIMS (BDE).....	104
DISADVANTAGED BUSINESS ENTERPRISE PARTICIPATION (BDE).....	105
EQUAL EMPLOYMENT OPPORTUNITY (BDE).....	116
FRICTION AGGREGATE (BDE) .....	119
HOT-MIX ASPHALT - DENSITY TESTING OF LONGITUDINAL JOINTS (BDE) .....	122
HOT MIX ASPHALT – PRIME COAT (BDE) .....	124
PAVEMENT PATCHING (BDE).....	128
PROGRESS PAYMENTS (BDE).....	128
TRACKING THE USE OF PESTICIDES (BDE).....	129
WARM MIX ASPHALT (BDE).....	129
WEEKLY DBE TRUCKING REPORTS (BDE).....	131

WORKING DAYS (BDE)..... 131  
VETERAN BUSINESS PROGRAM ..... 131

--This page is intentionally left blank.--

Revised 4/16/15

- (c) FRAP and/or RAS Usage Limits. Type 1 or Type 2 RAS may be used alone or in conjunction with FRAP in HMA mixtures up to a maximum of 5.0% by weight of the total mix.

When FRAP is used alone or FRAP is used in conjunction with RAS, the percent of virgin asphalt binder replacement (ABR) shall not exceed the amounts indicated in the table below for a given N Design.

Max Asphalt Binder Replacement for FRAP with RAS Combination

HMA Mixtures <sup>1/2/4/</sup>	Maximum % ABR		
	Binder/Leveling Binder	Surface	Polymer Modified <sup>3/</sup>
Ndesign			
30L	50	40	30
50	40	35	30
70	40	30	30
90	40	30	30
4.75 mm N-50			40
SMA N-80			30

- 1/ For HMA "All Other" (shoulder and stabilized subbase) N-30, the percent asphalt binder replacement shall not exceed 50% of the total asphalt binder in the mixture.
- 2/ When the binder replacement exceeds 15 percent for all mixes, except for SMA and IL-4.75, the high and low virgin asphalt binder grades shall each be reduced by one grade (i.e. 25 percent binder replacement using a virgin asphalt binder grade of PG64-22 will be reduced to a PG58-28). When constructing full depth HMA and the ABR is less than 15 percent, the required virgin asphalt binder grade shall be PG64-28.
- 3/ When the ABR for SMA or IL-4.75 is 15 percent or less, the required virgin asphalt binder shall be SBS PG76-22 and the elastic recovery shall be a minimum of 80. When the ABR for SMA or IL-4.75 exceeds 15%, the virgin asphalt binder grade shall be SBS PG70-28 and the elastic recovery shall be a minimum of 80.
- 4/ FWhen FRAP or RAS is used alone, the maximum percent asphalt binder replacement designated on the table shall be reduced by 10 percent.

Revised 4/16/15