

STRUCTURE NUMBER	STATION	OFFSET	STRUCTURE TYPE	TOP OF INLET ELEV	THROAT ELEV	INVERT ELEV				REMARKS
						N	S	E	W	
599	2+00	72.0' LT	INLETS, TYPE A	442.00	N/A			439.00		TYPE 8 GRATE
600	2+00	62.0' LT	MANHOLE, TYPE A 9' DIA	442.25	N/A	432.52	432.40	EX 432.72	438.50	TYPE 1 FRAME, CLOSED LID
601	3+40	29.5' LT	MANHOLE, TYPE A 8' DIA	446.00	N/A	432.90	432.80	440.55		TYPE 1 FRAME, CLOSED LID
602	3+40	14.2' LT	INLETS, SPECIAL	446.88	446.17			441.75	441.65	
603	4+39	23.0' LT	INLETS, SPECIAL	445.53	444.82	441.33		441.43		
604	3+40	14.0' RT	INLETS, SPECIAL	446.88	446.17				442.75	
605	4+39	14.0' RT	INLETS, SPECIAL	445.67	444.96			442.10	442.00	
606	4+67	42.0' LT	MANHOLE, TYPE A 9' DIA	445.87	N/A	433.25	433.15	440.90 SE	435.15	TYPE 1 FRAME, CLOSED LID
608	5+81	14.1' LT	INLETS, SPECIAL	445.15	444.44	433.74	433.59	436.57	438.00	
610	5+81	22.0' RT	INLETS, SPECIAL	445.06	444.35	437.05		439.31	436.95	DESIGN D, SEE DN, DD-01

**NOTES:**

- FOR LOCATIONS WHERE PROPOSED STRUCTURES CONNECT TO EXISTING STORM SEWERS, ONLY THE PORTION OF THE EXISTING PIPE NECESSARY FOR INSTALLATION OF THE INLET OR MANHOLE SHALL BE CUT AND REMOVED. THE PROPOSED STRUCTURE SHALL BE PROVIDED WITH ADEQUATELY SIZED OPENINGS SUCH THAT THE EXISTING PIPE MAY BE CONNECTED AT ITS EXISTING INVERT ELEVATION. REMOVAL OF EXISTING STORM SEWER, ANY PROPOSED CONCRETE COLLARS AND ANY SHORT LENGTHS OF PROPOSED STORM SEWER REQUIRED FOR CONNECTION, WILL NOT BE PAID FOR SEPARATELY, BUT SHALL BE INCLUDED IN THE CONTRACT UNIT PRICE PER EACH FOR THE TYPE AND KIND OF DRAINAGE STRUCTURE TO BE INSTALLED.
- FOR PROPOSED STORM SEWER CONNECTIONS TO EXISTING STRUCTURES, THE CONNECTION AND REMOVAL OF CONCRETE TO MAKE NECESSARY HOLES IN THE EXISTING STRUCTURES WILL NOT BE PAID FOR SEPARATELY, BUT SHALL BE INCLUDED IN THE CONTRACT UNIT PRICE PER FOOT FOR STORM SEWERS OF THE SIZE, TYPE, CLASS AND OF THE PARTICULAR KIND OF MATERIAL WHEN SPECIFIED.