SEE DRAWING SAN-02
MATCH LINE STA. 133+00.00

MATCH LINE STA. 139+00.00

10" SAN

8" SAN

US 45 (LAGRANGE RD)

133 | 134 | 135+00 | 136 | 137 | 138

SANITARY FORCE MAIN TO BE ABANDONED & FILLED WITH FLOWABLE FILL

4" AND 6" SAN (FORCE MAIN)

PROPOSED 6" SANITARY FORCE MAIN

PROPOSED 4" SANITARY FORCE MAIN

CONTRACTOR TO FOLLOW MANUFACTURER'S RECOMENDATIONS FOR MAXIMUM PIPE & JOINT DEFLECTIONS FOR BEND

PLAN
SURVEYED
PLOTTED
ALIGNMENT CHECKED
RT. OF WAY CHECKED
CADD FILE NAME
NOTE BOOK
NO.
BY
DATE

PROFILE
SURVEYED
PLOTTED
CROSS SECTIONS CHECKED
BM. NOTED
STRUCTURE NOTATIONS CHKD
NOTE BOOK
NO.

725
720
715
710
705
700

NG GROUND LINE

6.0' MIN. (TYP.)

6.0' MIN. (TYP.)

135+85

TIE IN TO EXISTING MANHOLE
MH 61385
STA 135+85
NORTHING 1794396.0
EASTING 1115816.53
INVERT (IN) 709.47
INVERT (OUT) 708.97

PROPOSED 4" FORCE MAIN AND 6" FORCE MAIN PVC SDR 21

PROPOSED 4" FORCE MAIN AND 6" FORCE MAIN PVC SDR 21

VPC +91.89
EL. 723.24

| | | |