



EXISTING LIGHTING CONTROLLERS "RWP-1" & "H-2" WIRING MODIFICATION DIAGRAM N.T.S. (NOTES 2, 3, 4)

LEGEND:

PROPOSED LIGHTING UNIT: 400W, 240V PHASE TO NEUTRAL, HPS LUMINAIRE WITH TYPE III DISTRIBUTION, 45'-2" ALUMINUM POLE SHAFT ON 24" DIAMETER CONCRETE FOUNDATION, 47'-6" MOUNTING HEIGHT, 12'-0" MAST ARM, WITH 5A FUSES AND T-BASE (RED PHASE-OPEN SYMBOL, BLACK PHASE-SHADED SYMBOL)

EXISTING LIGHTING UNIT WITH RECEPTACLE TO BE RELOCATED (LIGHTING UNIT ON RED PHASE-OPEN SYMBOL, BLACK PHASE-SHADED SYMBOL) (RECEPTACLE ON ORANGE PHASE-OPEN SYMBOL, BROWN PHASE-SHADED SYMBOL)

EXISTING LIGHTING POLE TO BE RELOCATED WITH NEW 250 W HPS FIXTURE AND GFCI RECEPTACLE (LIGHTING UNIT ON RED PHASE-OPEN SYMBOL, BACK PHASE-SHADED SYMBOL) (RECEPTACLE ON ORANGE PHASE-OPEN SYMBOL, BROWN PHASE-SHADED SYMBOL)

⇒ PROPOSED 120V, 20A, GFCI RECEPTACLE ON PROPOSED LIGHTING UNIT (ORANGE PHASE-OPEN SYMBOL, BROWN PHASE-SHADED SYMBOL)

⇒E EXISTING RECEPTACLE INSTALLED BY OTHERS (ORANGE PHASE-OPEN SYMBOL, BROWN PHASE-SHADED SYMBOL)

E EXISTING ROADWAY LIGHTING OR RECEPTACLE CONTROLLER AS INDICATED

HH EXISTING ROADWAY LIGHTING HANDHOLE TO BE RELOCATED

HH EXISTING ROADWAY LIGHTING HANDHOLE

--- PROPOSED ELECTRICAL CONDUCTORS: SIZE AND OUANTITY AS INDICATED

ELECTRICAL CONDUCTORS: EXISTING OR INSTALLED IN EARLIER CONSTRUCTION STAGE

NOTES:

- 1. SEE DRAWING E-1 FOR ELECTRICAL ABBREVIATIONS. SEE DRAWING E-2 FOR ELECTRICAL GENERAL NOTES.
- 2. WIRING DIAGRAM ONLY SHOWS THE CHANGES BEING MADE TO THE CONTROLLERS. EXISTING LOADS ON THE CONTROLLERS ARE NOT SHOWN FOR CLARITY.
- 3. COLOR CODING OF PROPOSED CONDUCTORS FOR 240/480V, 10, 3W LIGHTING SYSTEM IS AS FOLLOWS:

"A" PHASE - RED
"B" PHASE - BLACK
NEUTRAL - WHITE
GROUND - GREEN

4. COLOR CODING OF PROPOSED CONDUCTORS FOR 120/240V, 10, 3W RECEPTACLE SYSTEM IS AS FOLLOWS:

"A" PHASE - ORANGE
"B" PHASE - BROWN
NEUTRAL - GRAY
GROUND - GREEN

100 S. WACKER DR. SUITE 500 CHICAGO II., 60606 TEL (312)-939-4090 FAX (312)-939-4090

DESIGNED - JLW REVISED US 45 (LaGRANGE ROAD) FILE NAME = USER NAME = michal_bartusiewicz SECTION COUNTY STATE OF ILLINOIS 160M61-SHT-E42.dgr DRAWN CJM REVISED EXISTING LIGHTING CONTROLLERS "RWP-1" & "H-2" 330 103R-4 COOK 877 453 PLOT SCALE = 2.0000000 '/ in. CHECKED - KMY REVISED **DEPARTMENT OF TRANSPORTATION** WIRING MODIFICATION DIAGRAM E-42 CONTRACT NO. 60M61 SCALE: NONE SHEET PLOT DATE = 3/15/2013 DATE 03/13/2013 REVISED 1 OF 1 SHEETS STA. D160M61-SHT-E42.dgn 3/15/2013 2:27:27 PM